



August 19, 2024

Mr. Mo Madani (mo.madani@myfloridalicense.com)
Florida Building Commission

Dear Mr. Madani,

On behalf of Carrier Global Corporation, I would like to express my support for the proposed 3rd Glitch for the 8th Edition (2023) of the FBC.

With the upcoming effective date of January 1, 2025, of the restrictions on the use of hydrofluorocarbons under 40 CFR 84.54, it is critical that refrigeration systems using A2L refrigerants be installed in accordance with the latest edition of the safety standard, ASHRAE 15.

Therefore, we urge the Mechanical TAC and the Commission to **approve the update of the ASHRAE 15 reference to the 2022 Edition (ASHRAE 15-22), including all addenda issued through July 31, 2024**

Under your Office's direction, I am confident that this update will be implemented in the Florida Building Code – Mechanical soon and I remain available to provide any additional information you may require.

Respectfully yours

A handwritten signature in black ink, appearing to be "D. Taudin", with a long horizontal line extending to the right.

Dominique Taudin
Senior Fellow, Codes & Standards
Carrier Global Corporation