

FABRICATED BY:  
RM ENTERPRISES  
352 TALL PINES ROAD SUITE A-1  
WEST PALM BEACH, FL 33413  
PH# 561-682-1225

**FL3203-R1**  
FLORIDA APPROVED

## **MOUNTING INSTRUCTIONS**

CONDENSING UNIT TIE DOWN TO BE AS FOLLOWS:  
USE THE RM CLIP SCREW TO A CONCRETE SLAB OR ALUMINUM ROOF STANDS WITH 1  
EACH  $\frac{1}{4} \times 1 \frac{3}{4}$  TAPCON OR EQUAL. ALSO USE 2 EA  $\frac{3}{16}'' \times \frac{3}{8}''$  SCREWS ATTACHED TO  
CONDENSING UNIT. 4 CLIPS ARE TO BE MOUNTED TO EACH CONDENSING UNIT.  
THESE CLIPS ARE DESIGNED TO WORK WITH A MAX. SIZE CONDENSING UNIT OF  
4' X 4' X 4'.

THIS IS FOR GROUND MOUNTED UNITS OR CONCRETE ROOF DECKS. ALSO, CAN BE  
USE WITH ALUMINUM ROOF STANDS. THESE CLIPS ARE G-90 RATED FOR CORRISION  
COASTAL SITUATIONS. THE DESIGN MEETS THE REQUIREMENTS OF THE **FLORIDA  
BUILDING CODE 2004, CHAPTER 301.13 WIND RESISTANCE, ASCE 7-2002, 150 MPH  
WINDS AND SBCCI. THESE RM CLIPS HAVE A FLORIDA APPROVAL #3203 R1.**