


NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010350-R1
DATE: 09/01/2010
CERTIFICATION PROGRAM: Structural
COMPANY: Quaker
CODE: 031-1
REVISION DATE: 03/11/2013

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Quaker Window Products 504 Highway 63 South Freeburg, MO 65035	Series "K200 (#1350)" Thermally-Broken Aluminum Horizontal Sliding Window Configuration: XO Glazing: Insulating Glass (Annealed) Frame: W-1803mm(71") H-1524mm(60") Sash: W-908mm(35.75") H-1453mm(57.19") STP: Pos+3600 Pa (75.19 psf) Neg-3600 Pa (75.19 psf)

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-05	HS-C50 1803 x 1524 (71 x 60)

Product Tested By: Architectural Testing, Inc.
Report No: 98882.01-801-47
Expiration Date: February 28, 2014

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be 'S. H. O.', written over a horizontal line.

NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122