


NOTICE OF PRODUCT CERTIFICATION




CERTIFICATION NO: NI009663-R2
DATE: 10/23/2008
CERTIFICATION PROGRAM: Structural
COMPANY: Quaker
CODE: 031-1
REVISION DATE: 12/10/2012

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Quaker Window Products 504 Highway 63 South Freeburg, MO 65035	Series "K200(4000)" Thermally-Broken Aluminum Fixed Window Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-1632mm(64") H-1803mm(71") DLO: W-1473mm(58") H-1734mm(68.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-05 ASTM F588-04	FW-HC60 1632 x 1803 (64 x 71) FER-Passed

Product Tested By: Architectural Testing, Inc.
 Report No: 82361.01-801-47/W-1536
 Expiration Date: April 30, 2016

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
 Fax: (804) 684-5122