

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011736-R1
DATE: 12/09/2013
CERTIFICATION PROGRAM: Structural
COMPANY: The Door Store
CODE: 1367-1
REVISION DATE: 12/10/2013

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
The Door Store of America DBA DSA Master Crafted Doors, LLC 10681 World Trade Boulevard Raleigh, NC 27617	"7/0 x 8/0 Double Full Lite/2PNL" Double Wood Side Hinged Doors Configuration: XX Glazing: IG: Exterior-5/32" Tempered Glass/ Interior-Laminate-1/8" Annealed Glass/0.090" PVB Interlayer by DuPont/1/8" Annealed Glass Frame: W-2235mm(88") H-2515mm(99") DLO: W-787mm(31") H-2083mm(82")

SPECIFICATION	PRODUCT RATING
ASTM E283-04/E330-02 ASTM E1886-05/E1996-09	Design Pressure: +50/-50 psf Wind Zone 4-Missile Level D Qualifies Configurations: X or XX

Product Tested By: American Test Lab, Inc.
Report No: ATLNC 0924.01-13
Expiration Date: September 30, 2017

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122