

398 E. Dania Beach Blvd.
Suite 338
Dania Beach, FL 33004
954.399.8478 PH
954.744.4738 FX
contact@buildingdrops.com

August 17, 2012

TO: Whom It May Concern

FROM: Hermes F. Norero, P.E.

Registered Florida Professional Engineer #73778

MANUFACTURER: Quaker Window Products Co. Inc.

504 Highway 63 South Freeburg, MO 65035

PRODUCT NAME: Series 340(E700) Frame with Impact Louver Insert

SUBJECT: Equivalency of Standards

Dear Sir (Madam),

Various test standards have been evaluated for differences in test methodology, if any, between tested editions of the test standards listed below and those editions referenced in the 2010 Florida Building Code. Quaker Window Products Co. Inc. has tested their products to the following test standard edition(s):

- 1) AAMA 450-00
- 2) ASTM E330-97

Chapter 35 of the 2010 Florida Building Code references the following edition(s) of the above mentioned test standard(s):

- 1) AAMA 450-06
- 2) ASTM E330-02

The AAMA 450 rating option for this product is Option 1. Section 4, Referenced Documents, has had an addition of referenced standards and an update to the referenced standard years. All referenced standards have been found to be equivalent for the purpose of this approval.

ASTM E330-97 & -02 referenced standard years have been deemed equivalent per Rule 9N-3.015, Equivalence of Standards.

After review of the above mentioned referenced standards and editions, it has been found that no significant technical changes have been made to the test standards that would affect the results of the test and the compliance of such test to the 2010 Florida Building Code. All test results meet minimum requirements of the 2010 Florida Building Code.




398 E. Dania Beach Blvd. Suite 338 Dania Beach, FL 33004 954.399.8478 PH 954.744.4738 FX contact@buildingdrops.com

Please note that I do not have, nor will I acquire, a financial interest in any company manufacturing or distributing the product(s) for which the reports are being issued.

I also do not have, nor will I acquire, any financial interest with the Laboratory that performed the test(s), or with the Engineer witnessing the test(s) and sealing the test report(s).

Respectfully submitted,



Hermes F. Norero, P.E. Florida Registered Professional Engineer #73778