

Lucas A. Turner, P.E., MBA

2080 Mauve Terrace
North Port, FL 34286
Ph. 941-380-1574

November 28, 2011

Equivalence of Product Standards

Product Description:

Series 8100 PVC Single Hung, as detailed in Installation Instructions and Evaluation Reports CWS-155B, CWS-295A, CWS-369B, CWS-440A, and CWS-491A

Manufacturer:

Custom Window Systems, Inc. 1900 SW 44th Ave, Ocala, FL 34474

Equivalent Standards:

ASTM E 1996-02/05 and ASTM E 1996-06

Assessment:

Various configurations of the product indicated above have been tested to ASTM E 1996-02 and/or ASTM E 1996-05. I have determined that for the indicated product as defined in the indicated Installation Instructions and Evaluation Reports, that both ASTM E 1996-02 and ASTM E 1996-05 are equivalent to ASTM E 1996-06 as referenced in the 2010 Florida Building Code.



11/28/11
Lucas A. Turner, P.E.
FL P.E. 58201

