

December 14, 2011

Florida Department of Business and Professional Regulation  
1940 North Monroe Street  
Tallahassee, FL 32399

Regarding: Transparent Protection Systems, Inc.  
ClearGuard Polycarbonate Storm Panels (HVHZ)  
FLB #08-TPS-0007

To Whom It May Concern:

This office has reviewed test reports showing weathering performance of the plastic material used in the above-noted product. These test reports pertain to testing performed in accordance with ASTM G26 Standard Practice for Operating Light-Exposure Apparatus (Xenon-Arc Type) With and Without Water for Exposure of Nonmetallic Materials. This standard is not referenced in the 2010 Florida Building Code; however, for the purpose of determining the performance of the product, this standard is equivalent to ASTM G155-05a, which is an adopted standard in the above referenced building code.

Respectfully,

**FRANK L. BENNARDO**  
**PROFESSIONAL ENGINEER**  
**STATE OF FLORIDA**  
**NO. 1082011**  
**DEC 10 2011**  
**1082011**  
Frank L. Bennardo, P.E.  
Frank L. Bennardo, P.E., Inc.  
FLB #08-TPS-0007  
Cert of Auth #9885