

February 3, 2015


Florida Department of Business and Professional Regulation  
1940 North Monroe Street  
Tallahassee, FL 32399

Regarding: Transparent Protection Systems, Inc.  
ClearGuard Polycarbonate Storm Panels (HVHZ)  
FLB #14-1509

To Whom It May Concern:

This office has reviewed test reports showing weathering performance of the plastic material used in the above-noted product. These test reports pertain to testing performed in accordance with ASTM G26 Standard Practice for Operating Light-Exposure Apparatus (Xenon-Arc Type) With and Without Water for Exposure of Nonmetallic Materials. This standard is not referenced in the Florida Building Code Fifth Edition (2014); however, for the purpose of determining the performance of the product, this standard is equivalent to ASTM G155-05a, which is an adopted standard in the above referenced building code.

Respectfully,



Frank L. Bennardo, P.E.  
**Frank L. Bennardo, P.E., Inc.**  
FL PE 0046549  
Cert of Auth #9885