



# BUILDING DROPS

A Perfect Solution in Every Drop

Certificate of Authorization: 29578

398 East Dania Beach Blvd.  
Suite 338  
Dania Beach, FL 33004  
954.399.8478 PH  
954.744.4738 FX  
contact@buildingdrops.com

## Product Evaluation Report *of*

**The Folding Sliding Door Company**  
**HD82-70 MM Folding Outfolding Door System**

*for*  
**Florida Product Approval**

**FL# FL16291**

**Report No. 3624**

**5<sup>th</sup> Edition (2014) Florida Building Code**


**Method: 1-D (Engineering Evaluation)**  
**Category: Doors**  
**Sub – Category: Swinging**

**Product: HD82-70 MM Folding Outfolding Door System**  
**Material: Aluminum 6063-T5**  
**Product Dimensions: 223.75" x 96.0625" (Tested Size)**

**Prepared For:**  
**The Folding Sliding Door Company**  
**240 Spring View Commerce Drive, Bldg 1**  
**Debary, FL 32713**

**Prepared by:**  
**Hermes F. Norero, P.E.**  
Florida Professional Engineer # 73778  
Date: 04/30/2015

Contents:  
Evaluation Report      Pages 1 – 4



Hermes F. Norero, P.E.  
Florida No. 73778



# BUILDING DROPS

A Perfect Solution in Every Drop

Certificate of Authorization: 29578

FL#: FL16291

Date: 04/30/15

Report No: 3624

---

**Manufacturer:** The Folding Sliding Door Company

**Product Category:** Exterior Doors

**Product Sub-Category:** Swinging Exterior Door Assemblies

**Compliance Method:** State Product Approval Method (1)(d)

**Product Name:** HD82-70 MM Folding Outfolding Door System  
(Non-Impact)  
223.75" x 96.0625" (Tested Size)

**Scope:** This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL # 73778) for **The Folding Sliding Door Company** based on Method 1d of the State of Florida Product Approval, Florida Department of Business and Professional Regulation - Florida Building Commission.

Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the Florida Building Code.

See Installation Instructions **FSD004**, signed and sealed by Hermes F. Norero, P.E. (FL # 73778) for specific use parameters.

## Limits of Use:

1. This product has been evaluated and is in compliance with the Florida Building Code, excluding the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the Florida Building Code and does require an impact resistant covering.
4. Site conditions that deviate from the details of drawing **FSD004**, require further engineering analysis by a licensed engineer or registered architect.
5. See Installation Instructions **FSD004**, for size and design pressure limitations.



# BUILDING DROPS

A Perfect Solution in Every Drop

Certificate of Authorization: 29578

**FL#: FL16291**

Date: 04/30/15

Report No: 3624

---

**Quality Assurance:**

The manufacturer has demonstrated compliance of products in accordance with the Florida Building Code for manufacturing under a quality assurance program audited by an approved quality assurance entity through **National Accreditation Management Institute**. (FBC Organization # QUA1789).

**Performance Standards:**

The product described herein has been tested and evaluated per:

- TAS 202-94
- ASTM E 1300-04

**Referenced Data:**

1. Product Testing performed by **National Certified Testing Laboratory, Inc.** (FBC Organization # TST9341)  
Report #: NCTL-210-3846-1, Report Date: 02/01/2013
2. Quality Assurance  
**National Accreditation Management Institute**  
(FBC Organization #: QUA1789)



# BUILDING DROPS

A Perfect Solution in Every Drop

Certificate of Authorization: 29578

FL#: FL16291

Date: 04/30/15

Report No: 3624

**Installation:** 1. Approved anchor types and substrates are as follows:

**Through Frame Installation:**

- A. For two by (2X) wood buck substrate, use **#12 Wood Screw** type installation anchors of sufficient length to achieve a minimum embedment of 3" into the wood substrate.
- B. For concrete or masonry substrate where one by (1X), non-structural, wood bucking is employed **OR** where wood bucking is not employed, use **3/16" diameter ITW Tapcon or Elco Ultracons** type concrete screw anchors of sufficient length to achieve minimum embedment of 1 3/4" into concrete or masonry.
- C. Alternatively, for concrete/masonry substrates, anchors may be **7.5 mm (5/16" Nominal) Timco T30 Torx Concrete Screws**, of sufficient length to achieve 1 3/4" minimum embedment with a minimum 2 1/2" edge distance.
- D. For steel substrate (Min. 18 ga. steel, min.  $f_y = 33$  ksi), use **#12 TEK Screw** type steel stud anchors of sufficient length to achieve minimum 3 threads penetration beyond steel structure.

**Design Pressure:**

Refer to Installation Instructions (**FSD004, Sheet 8**) for applicable design pressures.

**Installation Method:**

Refer to Installation Instructions (**FSD004**) for anchor spacing, methods, locations, and more details of the installation requirements.