

**CODE ADMINISTRATION TECHNICAL ADVISORY COMMITTEE
CONCURRENT WITH THE
ELECTRICAL TECHNICAL ADVISORY COMMITTEE
TELECONFERENCE MEETING FROM TALLAHASSEE, FLORIDA**

WEB URL <https://global.gotomeeting.com/join/317261677>

AUDIO: DIAL-IN NUMBER 1 866-99-4679

CONFERENCE CODE: 317-261-677

November 27, 2018

10:00 A.M.

Minutes

CODE ADMINISTRATION TAC PRESENT:

Shane Gerwig, Chairman
Bob Boyer
Diana Worrall

David Gilson
John O'Connor

CODE ADMINISTRATION TAC NOT PRESENT:

Hamid Bahadori
Michael Guerasio

Richard Goff
Don Brown

STAFF PRESENT:

Mo Madani
Justin Vogel
Jim Hammers

Thomas Campbell
Chris Howell
Marlita Peters

Welcome:

Time: 10:03 a.m.

Ms. Peters welcomed everyone to the concurrent teleconference call of the Code Administration TAC and Electrical TAC.

Roll Call:

Ms. Peters performed roll call for the Code Administration TAC. A quorum was determined with 5 members present.

Agenda Approval:

Commissioner Boyer entered a motion to approve the agenda for today's meeting as posted. Mr. O'Connor seconded the motion. The motion passed unanimously with a vote of 5 to 0.

Approval of Minutes from July 26, 2018:

Commissioner Boyer entered a motion to approve the minutes from July 26, 2018 as posted. Mr. O'Connor seconded the motion. The motion passed unanimously with a vote of 5 to 0.

DS2018-070 by Michael Savage, Sr. of Marion County Department of Building Safety:

Mr. Savage, petitioner was present on the call and provided detailed background of this request for clarification.

Mr. Madani provided the background on the petition and full staff analysis.

Question: Due to the adopted provisions of the Florida Building Code, notably Sections 102.4, 102.4.1, and E3901.2, are sun rooms, namely Category III, required to comply with the receptacles spacing requirements specifically required under the FBC Residential code?

Answer:

Option #1/Petitioner:

The Petitioner respectfully believes the answer to the question is yes. Due to the prescriptive requirements of the Code as noted in E3901.2, E3901.2 and E3901.2.2, and the conflicts provision noted under Section 102.4.1, then it is clear sun rooms are required to meet the receptacles spacing requirements of the code.

DS2018-070 by Michael Savage, Sr. of Marion County Department of Building Safety (cont.):

Option #2/Staff:

No. The provisions of Section R301.2.1.1 of the FBC, Residential and AAMA 2100 as referenced from within section R301.2.1.1 are more specific than the provisions of Section E3901.2 of the FBC, Residential with regard to the definition of sunrooms and the placement of receptacle outlets, and therefore according to Section 102.1 of the FBC, Building, the requirements of Section E3901.2 including the receptacles spacing requirements do not apply to the projects in question. The electrical requirements for the project in question are subject to the requirements of AAMA 2100.

Public Comment:

Joe Belcher, FHBA and National Aluminum Association stated he is in support of the staff analysis.

Mr. O'Connor entered a motion to accept staff analysis option #2. Commissioner Gilson seconded the motion. The motion passed unanimously with a vote of 5 to 0.

Final Roll Call:

There being no further business before the TAC, Ms. Peters performed a closing roll call and there were 5 members still present on the line.

Adjourn:

The meeting was adjourned at 10:33 a.m.