St. Johns County Board of County Commissioners

BUILDING SERVICES DIVISION Building Department

4040 LEWIS SPEEDWAY SAINT AUGUSTINE, FLORIDA 32084



PHONE:

(904)827-6800 (904) 827-6849

6/2/08

Florida Building Commission Paula P Ford Clerk of the Commission Sadowisk Building 2555 Shumard Oak Boulevard Tallahassee, Florida 32399-2100

FILED, on this date, with the designated Clerk receipt of which is hereby

acknowledged.

Re: Petition for Declaratory Statement before the Florida Building Control Palasion Clerk

St. Johns Building Department James Paula Plans Examiner PX 1165 4040 Lewis Speedway St. Augustine, Florida 32084 904-827-6815 904-827-6849 fax jpaula@sjcfl.us

Subject: Building plan review of a three story single family pile supported structure located seaward of the DEP CCCL line

Questions:

- FBC 3109.4.1 requires that all habitable structures be elevated on a pile foundation. 1. Is it the intent of 3109.4.1 to require that decks and stairs attached to the structure also require a pile foundation?
- FBC 3109.4.1 requires a design ratio or pile spacing to pile diameter should not be less than 8: 1 2. Is it the intent of FBC 3109.4.1 to allow a design ratio or pile spacing to pile diameter of less than 8: 1? If "Yes", where is a lesser design ratio allowed?
- FBC 3109.3 requires that the bottom of the lowest horizontal structural member be located above the 100 3. year storm elevation.

Is it the intent of FBC 3109.3 to require that the bottom of the lowest horizontal structural member be located above the 100 year storm elevation when a portion of the lowest horizontal members fall landward of the CCCL line?

Sincerely

James Paula

Plans Examiner PX 1165