

RESIDENTIAL ENERGY CONSERVATION CODE DOCUMENTATION CHECKLIST**Florida Department of Business and Professional Regulation
Simulated Performance Alternative (Performance) Method**

Applications for compliance with the 2017 Florida Building Code, Energy Conservation via the residential Simulated Performance method shall include:

- A Form 405 report that documents that the Proposed Design complies with Section R405.3 of the Florida Energy Code. This form shall include a summary page indicating home address, e-ratio and the pass or fail status along with summary areas and types of components, whether the home was simulated as a worst-case orientation, name and version of the compliance software tool, name of individual completing the compliance report (1 page) and an input summary checklist that can be used for field verification (usually 4 pages/may be greater)
- Energy Performance Level (EPL) Display Card (one page)
- HVAC system sizing and selection based on ACCA Manual S or per exceptions provided in Section R403.7
- Mandatory Requirements (five pages)

Required prior to CO for the Performance method:

- Air Barrier and Insulation Inspection Component Criteria checklist (Table 402.4.1.1 - one page)
- A completed Envelope Leakage Test Report (usually one page)
- If Form R405 duct leakage type indicates anything other than "default leakage", then a completed Form R405 Duct Leakage Test Report (usually one page).

FLORIDA ENERGY EFFICIENCY CODE FOR BUILDING CONSTRUCTION


Florida Department of Business and Professional Regulation - Residential Performance Method

Project Name: Right-Energy® Florida 2014 Example Street: 1516 Ninth Street City, State, Zip: Tampa, FL 33601 Owner: Mr. and Mrs. Henry Wagner Design Location: FL, Tampa International AP	Builder Name: Wrightsoft Permit Office: Tampa Permit Number: 2222-1 Jurisdiction: Hillsborough County County: Hillsborough (Florida Climate Zone 2)
---	---

<table style="width: 100%;"> <tr> <td>1. New construction or existing</td> <td>New (From Plans)</td> </tr> <tr> <td>2. Single family or multiple family</td> <td>Single-Family</td> </tr> <tr> <td>3. Number of units, if multiple family</td> <td>1</td> </tr> <tr> <td>4. Number of bedrooms</td> <td>3</td> </tr> <tr> <td>5. Is this a worst case?</td> <td>No</td> </tr> <tr> <td>6. Conditioned floor area above grade (ft²)</td> <td>2100.00</td> </tr> <tr> <td> Conditioned floor area below grade (ft²)</td> <td>0</td> </tr> <tr> <td>7. Windows (340 ft²)</td> <td>Description Area (ft²)</td> </tr> <tr> <td> a. U-Factor:</td> <td>Sgl, U=0.032 299.58</td> </tr> <tr> <td> SHGC:</td> <td>SHGC=0.25</td> </tr> <tr> <td> b. U-Factor:</td> <td>Dbl, U=0.032 40.56</td> </tr> <tr> <td> SHGC:</td> <td>SHGC=0.25</td> </tr> <tr> <td> c. U-Factor:</td> <td></td> </tr> <tr> <td> SHGC:</td> <td></td> </tr> <tr> <td> d. U-Factor:</td> <td></td> </tr> <tr> <td> SHGC:</td> <td></td> </tr> <tr> <td></td> <td>Area Weighted Average Overhang Depth: 1.000 ft</td> </tr> <tr> <td></td> <td>Area Weighted Average SHGC: 0.250</td> </tr> <tr> <td>8. Floor types (2100.00 ft²)</td> <td>Insulation Area (ft²)</td> </tr> <tr> <td> a. Bg floor, light dry soil, on grade</td> <td>R=0.0 2100.00</td> </tr> <tr> <td> b. N/A</td> <td>R=</td> </tr> <tr> <td> c. N/A</td> <td>R=</td> </tr> </table>	1. New construction or existing	New (From Plans)	2. Single family or multiple family	Single-Family	3. Number of units, if multiple family	1	4. Number of bedrooms	3	5. Is this a worst case?	No	6. Conditioned floor area above grade (ft²)	2100.00	Conditioned floor area below grade (ft²)	0	7. Windows (340 ft²)	Description Area (ft²)	a. U-Factor:	Sgl, U=0.032 299.58	SHGC:	SHGC=0.25	b. U-Factor:	Dbl, U=0.032 40.56	SHGC:	SHGC=0.25	c. U-Factor:		SHGC:		d. U-Factor:		SHGC:			Area Weighted Average Overhang Depth: 1.000 ft		Area Weighted Average SHGC: 0.250	8. Floor types (2100.00 ft²)	Insulation Area (ft²)	a. Bg floor, light dry soil, on grade	R=0.0 2100.00	b. N/A	R=	c. N/A	R=	<table style="width: 100%;"> <tr> <td>9. Wall types (1728 ft²)</td> <td>Insulation</td> <td>Area (ft²)</td> </tr> <tr> <td> a. Frm wall, eifs ext, r-15 ca</td> <td>19.0</td> <td>1458.00</td> </tr> <tr> <td> b. Frm wall, stucco ext, r-15</td> <td>15.0</td> <td>270.00</td> </tr> <tr> <td> c. N/A</td> <td>R=</td> <td></td> </tr> <tr> <td> d. N/A</td> <td>R=</td> <td></td> </tr> <tr> <td>10. Ceiling types (2100 ft²)</td> <td>Insulation</td> <td>Area (ft²)</td> </tr> <tr> <td> a. Attic ceiling, asphalt s</td> <td>R=30.0</td> <td>2100.00</td> </tr> <tr> <td> b. N/A</td> <td>R=</td> <td></td> </tr> <tr> <td> c. N/A</td> <td>R=</td> <td></td> </tr> <tr> <td>11. Ducts</td> <td>R</td> <td>Area (ft²)</td> </tr> <tr> <td> a. Sup:Living AH/Ret:Living AH/AH:Living AH</td> <td>8.0</td> <td>222.79</td> </tr> <tr> <td> b.</td> <td></td> <td></td> </tr> <tr> <td>12. Cooling systems</td> <td>kBtu/hr</td> <td>Efficiency</td> </tr> <tr> <td> a. Split air source heat pump</td> <td>20.2</td> <td>SEER: 14.0</td> </tr> <tr> <td>13. Heating systems</td> <td>kBtu/hr</td> <td>Efficiency</td> </tr> <tr> <td> a. Split air source heat pump</td> <td>22.4</td> <td>HSPF: 8.2</td> </tr> <tr> <td>14. Hot water systems</td> <td></td> <td></td> </tr> <tr> <td> a. Electric conventional (40 gal)</td> <td></td> <td>Cap: 40 gal EF: 0.96</td> </tr> <tr> <td> b. Conservation features</td> <td></td> <td>Solar: FEF=3.0</td> </tr> <tr> <td>15. Credits</td> <td></td> <td>Solar WH</td> </tr> </table>	9. Wall types (1728 ft²)	Insulation	Area (ft²)	a. Frm wall, eifs ext, r-15 ca	19.0	1458.00	b. Frm wall, stucco ext, r-15	15.0	270.00	c. N/A	R=		d. N/A	R=		10. Ceiling types (2100 ft²)	Insulation	Area (ft²)	a. Attic ceiling, asphalt s	R=30.0	2100.00	b. N/A	R=		c. N/A	R=		11. Ducts	R	Area (ft²)	a. Sup:Living AH/Ret:Living AH/AH:Living AH	8.0	222.79	b.			12. Cooling systems	kBtu/hr	Efficiency	a. Split air source heat pump	20.2	SEER: 14.0	13. Heating systems	kBtu/hr	Efficiency	a. Split air source heat pump	22.4	HSPF: 8.2	14. Hot water systems			a. Electric conventional (40 gal)		Cap: 40 gal EF: 0.96	b. Conservation features		Solar: FEF=3.0	15. Credits		Solar WH
1. New construction or existing	New (From Plans)																																																																																																								
2. Single family or multiple family	Single-Family																																																																																																								
3. Number of units, if multiple family	1																																																																																																								
4. Number of bedrooms	3																																																																																																								
5. Is this a worst case?	No																																																																																																								
6. Conditioned floor area above grade (ft²)	2100.00																																																																																																								
Conditioned floor area below grade (ft²)	0																																																																																																								
7. Windows (340 ft²)	Description Area (ft²)																																																																																																								
a. U-Factor:	Sgl, U=0.032 299.58																																																																																																								
SHGC:	SHGC=0.25																																																																																																								
b. U-Factor:	Dbl, U=0.032 40.56																																																																																																								
SHGC:	SHGC=0.25																																																																																																								
c. U-Factor:																																																																																																									
SHGC:																																																																																																									
d. U-Factor:																																																																																																									
SHGC:																																																																																																									
	Area Weighted Average Overhang Depth: 1.000 ft																																																																																																								
	Area Weighted Average SHGC: 0.250																																																																																																								
8. Floor types (2100.00 ft²)	Insulation Area (ft²)																																																																																																								
a. Bg floor, light dry soil, on grade	R=0.0 2100.00																																																																																																								
b. N/A	R=																																																																																																								
c. N/A	R=																																																																																																								
9. Wall types (1728 ft²)	Insulation	Area (ft²)																																																																																																							
a. Frm wall, eifs ext, r-15 ca	19.0	1458.00																																																																																																							
b. Frm wall, stucco ext, r-15	15.0	270.00																																																																																																							
c. N/A	R=																																																																																																								
d. N/A	R=																																																																																																								
10. Ceiling types (2100 ft²)	Insulation	Area (ft²)																																																																																																							
a. Attic ceiling, asphalt s	R=30.0	2100.00																																																																																																							
b. N/A	R=																																																																																																								
c. N/A	R=																																																																																																								
11. Ducts	R	Area (ft²)																																																																																																							
a. Sup:Living AH/Ret:Living AH/AH:Living AH	8.0	222.79																																																																																																							
b.																																																																																																									
12. Cooling systems	kBtu/hr	Efficiency																																																																																																							
a. Split air source heat pump	20.2	SEER: 14.0																																																																																																							
13. Heating systems	kBtu/hr	Efficiency																																																																																																							
a. Split air source heat pump	22.4	HSPF: 8.2																																																																																																							
14. Hot water systems																																																																																																									
a. Electric conventional (40 gal)		Cap: 40 gal EF: 0.96																																																																																																							
b. Conservation features		Solar: FEF=3.0																																																																																																							
15. Credits		Solar WH																																																																																																							

Glass/Floor area: 0.162
Total Proposed Modified Loads: 54.63
PASS

Total Baseline Loads: 65.84

<p>I hereby certify that the plans and specifications covered by this calculation are in compliance with the Florida Energy Code.</p> <p>PREPARED BY: _____</p> <p>DATE: _____</p> <p>I hereby certify that this building, as designed, is in compliance with the Florida Energy Code.</p> <p>OWNER/AGENT: _____</p> <p>DATE: _____</p>	<p>Review of the plans and specifications covered by this calculation indicates compliance with the Florida Energy Code. Before construction is completed, this building will be inspected for compliance with Section 553.908 Florida Statutes.</p> <div style="text-align: right;">  </div> <p>BUILDING OFFICIAL: _____</p> <p>DATE: _____</p>
---	---

- Compliance requires certification by the air handler unit manufacturer that the air handler enclosure qualifies as certified factory-sealed in accordance with R403.2.2.1.
- Compliance requires an Air Barrier and Insulation Inspection Checklist in accordance with R402.4.1.1 and starting July 1, 2017, this project requires an envelope leakage test report with envelope leakage no greater than 7.0 ACH50 (R402.4.1.2).

Building Input Summary Report

PROJECT														
Title:	Right-Energy® Florida 2014	Bedrooms:	3	Address type:	Street address									
Building Type:	FLAsBuilt	Bathrooms:	1	Lot#:	Lot. 410-111									
Owner:	Mr. and Mrs. Henry Wagner	Conditioned Area:	2100	Block/Subdivision:	Lexington Crossing									
# of Units:	1	Total Stories:	1	Platbook:	111-11									
Builder Name:	Wrightsoft	Worst Case:	No	Street:	1516 Ninth Street									
Permit Office:	Tampa	Rotate Angle:	0	County:	Hillsborough									
Jurisdiction:	Hillsborough County	Cross Ventilation:	No	City, State, Zip:	Tampa, FL 33601									
Family Type:	Single-Family	Whole House Fan:	No											
New/Existing:	New (From Plans)	Terrain:	Ocean/Lake											
Year Construct:	2017	Shielding:	Suburban											
Comment:	Pre-construction													
CLIMATE														
✓	Design Location	TMY Site	IECC Zone	Design Temp 97.5 %	Design Temp 2.5 %	Int Design Temp Winter	Int Design Temp Summer	Heating Degree Days	Design Moisture	Daily Temp Range				
	FL, Tampa International AP	FL_Tampa_Intl_AP	2	43	91	70	75	0	53	Low				
BLOCKS														
#	Name	Area	Volume											
1	Living AH	2100.00 ft²	18900.00 ft³											
SPACES														
#	Area	Volume	Kitchen	Occupants	Bedrooms	Infil ID	Finished	Cooled	Heated					
1	Living	2100.00 ft²	18900.00 ft³	No	4	3	1	Yes	Yes	Yes				
FLOORS														
✓	#	Floor Type	Space	Perimeter	R-Value	Area	Tile	Wood	Carpet					
	1	Bg floor, light dry soil, on grade depth, carp 80	Living	162 ft	0	2100.00 ft²	0	0	0.8					
ROOF														
✓	#	Type	Materials	Roof Area	Gable Area	Roof Color	Solar Absor.	SA Tested	Emitt	Emitt Tested	Deck Insul.	Pitch (deg)		
	1	Gable or shed	RoofAsph	2661 ft²	100 ft²	Light	0.60	No	0.90	No	6	22		
ATTIC														
✓	#	Type	Ventilation	Vent Ratio (1 in)	Area	RBS	IRCC							
	1	Full attic	Vented	300	2100.00ft²	N	N							
CEILING														
✓	#	Ceiling Type	Space	R-Value	Area	Framing Fraction	Truss Type							
	1	Attic ceiling, asphalt s	Living	30	2100.00 ft²	0.10	--							
WALLS														
✓	#	Ornt	Adjacent To	Wall Type	Space	Cavity R-Value	Width Ft	Height In	Area	Sheathing R-Value	Framing Fraction	Solar Absor.	Below Grade%	
	1	N	Exterior	Frm wall, e	Living	19	30	0	9 0	270.0 ft²	4	0.25	0.75	0
	2	E	Exterior	Frm wall, e	Living	19	36	0	9 0	324.0 ft²	4	0.25	0.75	0
	3	S	Exterior	Frm wall, e	Living	19	50	0	9 0	450.0 ft²	4	0.25	0.75	0
	4	W	Exterior	Frm wall, e	Living	19	46	0	9 0	414.0 ft²	4	0.25	0.75	0
	5	-	Partition	Frm wall, s	Living	15	30	0	9 0	270.0 ft²	0	0.25	0.75	0
DOORS														
✓	#	Ornt	Door Type	Space	Storms	U-Value	Width Ft	Height In	Area					
	1	N	Door, wd sc type	Living	None	0.390	3 0	6 8	20.0 ft²					
	2	N	Door, wd sc type	Living	None	0.390	3 2	6 8	21.1 ft²					

WINDOWS														
✓ #	Ornt	Wall ID	Frame	Panes	NFRC	U-Factor	SHGC	Storms	Area	Depth	Overhang Separation	Interior Shade	Screening	
1	N	1	None	Single (Clear)	Yes	0.032	0.25	No	14.6ft²	1 ft 0 in	1 ft 4 in	Blinds 45°	outdoor	
2	N	1	None	Single (Clear)	Yes	0.032	0.25	No	30.0ft²	1 ft 0 in	1 ft 4 in	Blinds 45°	outdoor	
3	N	1	None	Single (Clear)	Yes	0.032	0.25	No	30.0ft²	1 ft 0 in	1 ft 4 in	Blinds 45°	outdoor	
4	E	2	None	Single (Clear)	Yes	0.032	0.25	No	45.0ft²	1 ft 0 in	1 ft 4 in	Blinds 45°	outdoor	
5	S	3	Wood	Double (Clear)	Yes	0.032	0.25	No	40.6ft²	1 ft 0 in	1 ft 4 in	Blinds 45°	outdoor	
6	S	3	None	Single (Clear)	Yes	0.032	0.25	No	135ft²	1 ft 0 in	1 ft 4 in	Blinds 45°	outdoor	
7	W	4	None	Single (Clear)	Yes	0.032	0.25	No	45.0ft²	1 ft 0 in	1 ft 4 in	Blinds 45°	outdoor	

GARAGE						
✓ #	Floor Area	Ceiling Area	Exposed Wall Perimeter	Avg. Wall Height	Exposed Wall Insulation	
1	440 ft²	440 ft²	54 ft	9 ft	19	

INFILTRATION								
#	Scope	Method	SLA	CFM 50	ELA	EqLA	ACH	ACH 50
1	Wholehouse	Blower Door	0.000401	2205	121.3	227.8	0.41	7.00

HEATING SYSTEM						
✓ #	System Type	Subtype	Efficiency	Capacity	Block	Ducts
1	Split air source heat pump		HSPF: 8.2	22.4 kBtu/hr	1	sys#1

COOLING SYSTEM								
✓ #	System Type	Subtype	Efficiency	Capacity	Air Flow	SHR	Block	Ducts
1	Split air source heat pump		SEER: 14.0	20.2 kBtu/hr	673 cfm	0.70	1	sys#1

HOT WATER SYSTEM								
✓ #	System Type	Subtype	Location	EF	Cap	Use	SetPnt	Conservation
1	Electric conventional			0.96	40 gal	60 gal	120 °F	None

SOLAR HOT WATER SYSTEM						
✓ FSEC Cert #	Company Name	System Model #	Collector Model #	Collector Area	Storage Volume	FEF
12345	Sample	SSWS-678	SSWC-123	35.0 ft²	70.0 gal	3.0

DUCTS												
✓ #	Location	--- Supply --- R-Value	Area	--- Return --- Location	Area	Leakage Type	Air Handler	CFM 25 Out	Percent Leakage	QN	RLF	HVAC # Heat Cool
1	Living AH	8.0	223 ft²	Living AH	15 ft²	Default Leakage	Living AH	(Default)	6.00			1 1

TEMPERATURES														
Programable Thermostat:							Ceiling Fans:							
Cooling	Heating	Venting	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
[X]	[X]	[X]	[X]	[X]	[X]	[X]	[X]	[X]	[X]	[X]	[X]	[X]	[X]	[X]
[X]	[X]	[X]	[X]	[X]	[X]	[X]	[X]	[X]	[X]	[X]	[X]	[X]	[X]	[X]
[X]	[X]	[X]	[X]	[X]	[X]	[X]	[X]	[X]	[X]	[X]	[X]	[X]	[X]	[X]
Thermostat Schedule:		Florida Building Code, 6th Edition					Hours							
Schedule Type		(2017)	1	2	3	4	5	6	7	8	9	10	11	12
Cooling (WD)	AM	75	75	75	75	75	75	75	75	75	75	75	75	75
	PM	75	75	75	75	75	75	75	75	75	75	75	75	75
Cooling (WEH)	AM	75	75	75	75	75	75	75	75	75	75	75	75	75
	PM	75	75	75	75	75	75	75	75	75	75	75	75	75
Heating (WD)	AM	72	72	72	72	72	72	72	72	72	72	72	72	72
	PM	72	72	72	72	72	72	72	72	72	72	72	72	72
Heating (WEH)	AM	72	72	72	72	72	72	72	72	72	72	72	72	72
	PM	72	72	72	72	72	72	72	72	72	72	72	72	72

ENERGY PERFORMANCE LEVEL (EPL) DISPLAY CARD

ESTIMATED ENERGY PERFORMANCE INDEX = 83
The lower the Energy Performance Index, the more efficient the home.

1516 Ninth Street, Tampa, FL 33601

1. New construction or existing	New (From Plans)		9. Wall Types	Insulation	Area (ft ²)
2. Single family or multiple family	Single-Family		a. Frm wall, eifs ext, r-15 ca	19.0	1458.00
3. Number of units, if multiple family	1		b. Frm wall, stucco ext, r-15	15.0	270.00
4. Number of bedrooms	3		c. N/A	R=	
5. Is this a worst case?	No		d. N/A	R=	
6. Conditioned floor area (ft ²)	2100.00		10. Ceiling Types	Insulation	Area (ft ²)
7. Windows**	Description	Area (ft ²)	a. Attic ceiling, asphalt s	R=30.0	2100.00
a. U-Factor:	Sgl, U=0.032	299.58	b. N/A	R=	
SHGC:	SHGC=0.25		c. N/A	R=	
b. U-Factor:	Dbl, U=0.032	40.56	11. Ducts	R	Area (ft ²)
SHGC:	SHGC=0.25		a. Sup:Living AH/Ret:Living AH/AH:Living AH	8.0	222.79
c. U-Factor:			12. Cooling systems	kBtu/hr	Efficiency
SHGC:			a. Split air source heat pump	20.2	SEER: 14.0
d. U-Factor:			b.		
SHGC:			13. Heating systems	kBtu/hr	Efficiency
Area Weighted Average Overhang Depth:	1.000 ft		a. Split air source heat pump	22.4	HSPF: 8.2
Area Weighted Average SHGC:	0.250		b.		
8. Floor Types	Insulation	Area (ft ²)	14. Hot water systems		Cap: 40 gal
a. Bg floor, light dry soil, on grade	R=0.0	2100.00	a. Electric conventional (40 gal)		EF: 0.96
b. N/A	R=		b. Conservation features		
c. N/A	R=		Solar:FEF=3.0		
			15. Credits Solar WH		

I certify that this home complied with the Florida Energy Efficiency Code for Building Construction through the above energy saving features which will be installed (or exceeded) in this home before final inspection. Otherwise, a new EPL Display Card will be completed based on installed Code compliant features.

Builder Signature: _____ Date: _____

Address of New Home: _____ City/FL Zip: _____



**Label required by Section 303.1.3 of the Florida Building Code, Energy Conservation, if not DEFAULT.

Florida Department of Business and Professional Regulations
Residential Whole Building Performance and Prescriptive Methods

ADDRESS: 1516 Ninth Street
Tampa, FL 33601

PERMIT #: 2222-1

MANDATORY REQUIREMENTS - See individual code sections for full details.

SECTION R401 GENERAL

- **R401.3 Energy Performance Level (EPL) display card (Mandatory).** The building official shall require that an energy performance level (EPL) display card be completed and certified by the builder to be accurate and correct before final approval of the building for occupancy. Florida law [Section 553.9085, Florida Statutes] requires the EPL display card to be included as an addendum to each sales contract for both presold and nonpresold residential buildings. The EPL display card contains information indicating the energy performance level and efficiencies of components installed in a dwelling unit. The building official shall verify that the EPL display card completed and signed by the builder accurately reflects the plans and specifications submitted to demonstrate compliance for the building. A copy of the EPL display card can be found in Appendix RD.
- **R402.4 Air leakage (Mandatory).** The building thermal envelope shall be constructed to limit air leakage in accordance with the requirements of Sections R402.4.1 through R402.4.5.

Exception: Dwelling units of R-2 Occupancies and multiple attached single family dwellings shall be permitted to comply with Section C402.5.

- **R402.4.1 Building thermal envelope.** The building thermal envelope shall comply with Sections R402.4.1.1 and R402.4.1.2. The sealing methods between dissimilar materials shall allow for differential expansion and contraction.
 - **R402.4.1.1 Installation.** The components of the building thermal envelope as listed in Table R402.4.1.1 shall be installed in accordance with the manufacturer's instructions and the criteria listed in Table 402.4.1.1, as applicable to the method of construction. Where required by the code official, an approved third party shall inspect all components and verify compliance.
 - **R402.4.1.2 Testing.** The building or dwelling unit shall be tested and verified as having an air leakage rate of not exceeding seven air changes per hour in Climate Zones 1 and 2, and three air changes per hour in Climate Zones 3 through 8. Testing shall be conducted in accordance with ANSI/RESET/ICC 380 and reported at a pressure of 0.2 inch w.g. (50 Pascals). Testing shall be conducted by either individuals as defined in Section 553.993(5) or (7), Florida Statutes or individuals licensed as set forth in Section 489.105(3)(f), (g), or (i) or an approved third party. A written report of the results of the test shall be signed by the party conducting the test and provided to the code official. Testing shall be performed at any time after creation of all penetrations of the building thermal envelope.

Exception: Testing is not required for additions, alterations, renovations, or repairs, of the building thermal envelope of existing buildings in which the new construction is less than 85 percent of the building thermal envelope.

During testing:

1. Exterior windows and doors, fireplace and stove doors shall be closed, but not sealed, beyond the intended weatherstripping or other infiltration control measures.
 2. Dampers including exhaust, intake, makeup air, backdraft and flue dampers shall be closed, but not sealed beyond intended infiltration control measures.
 3. Interior doors, if installed at the time of the test, shall be open.
 4. Exterior doors for continuous ventilation systems and heat recovery ventilators shall be closed and sealed.
 5. Heating and cooling systems, if installed at the time of the test, shall be turned off.
 6. Supply and return registers, if installed at the time of the test, shall be fully open.
- **R402.4.2 Fireplaces.** New wood-burning fireplaces shall have tight-fitting flue dampers and outdoor combustion air. Where using tight-fitting doors on factory-built fireplaces listed and labeled in accordance with UL 127, the doors shall be tested and listed for the fireplace. Where using tight-fitting doors on masonry fireplaces, the doors shall be listed and labeled in accordance with UL 907.
 - **R402.4.3 Fenestration air leakage.** Windows, skylights and sliding glass doors shall have an air infiltration rate of no more than 0.3 cfm per square foot (1.5 L/s/m²), and swinging doors no more than 0.5 cfm per square foot (2.6 L/s/m²), when tested according to NFRC 400 or AAMA/WDMA/CSA 101/I.S.2/A440 by an accredited, independent laboratory and listed and labeled by the manufacturer.

Exception: Site-built windows, skylights and doors.

MANDATORY REQUIREMENTS - (Continued)

- **R403.2.2.1 Sealed air handler.** Air handlers shall have a manufacturer's designation for an air leakage of no more than 2 percent of the design air flow rate when tested in accordance with ASHRAE 193.
- **R403.2.3 Building Cavities (Mandatory).** Building framing cavities shall not be used as ducts or plenums.
- **R403.3 Mechanical system piping insulation (Mandatory).** Mechanical system piping capable of carrying fluids above 105°F (41°C) or below 55°F (13°C) shall be insulated to a minimum of R-3.,
 - **R403.3.1 Protection of piping insulation.** Piping insulation exposed to weather shall be protected from damage, including that caused by sunlight, moisture, equipment maintenance, and wind, and shall provide shielding from solar radiation that can cause degradation of the material. Adhesive tape shall not be permitted.
- **R403.4.1 Circulating hot water systems (Mandatory).** Circulating hot water systems shall be provided with an automatic or readily accessible manual switch that can turn off the hot-water circulating pump when the system is not in use.
- **R403.4.3 Heat traps (Mandatory).** Storage water heaters not equipped with integral heat traps and having vertical pipe risers shall have heat traps installed on both the inlets and outlets. External heat traps shall consist of either a commercially available heat trap or a downward and upward bend of at least 3 1/2 inches (89 mm) in the hot water distribution line and cold water line located as close as possible to the storage tank.
- **R403.4.4 Water heater efficiencies (Mandatory).** Water heater efficiencies
 - **R403.4.4.1 Storage water heater temperature controls**
 - **R403.4.4.1.1 Automatic controls.** Service water heating systems shall be equipped with automatic temperature controls capable of adjustment from the lowest to the highest acceptable temperature settings for the intended use. The minimum temperature setting range shall be from 100°F to 140°F (38°C to 60°C).
 - **R403.4.4.1.2 shut down.** A separate switch or a clearly marked circuit breaker shall be provided to permit the power supplied to electric service systems to be turned off. A separate valve shall be provided to permit the energy supplied to the main burner(s) of combustion types of service water heating systems to be turned off.
 - **R403.4.4.2 Water heating equipment.** Water heating equipment installed in residential units shall meet the minimum efficiencies of Table C404.2 in Chapter 4 of the Florida Building Code, Energy Conservation, Commercial Provisions, for the type of equipment installed. Equipment used to provide heating functions as part of a combination system shall satisfy all stated requirements for the appropriate water heating category. Solar water heaters shall meet the criteria Section R403.4.4.2.1.
 - **R403.4.4.2.1 Solar water heating system.** Solar systems for domestic hot water production are rated by the annual solar energy factor of the system. The solar energy factor of a system shall be determined from the Florida Solar Energy Center Directory of Certified Solar Systems. Solar collectors shall be tested in accordance with ISO Standard 9806, Test Methods for Solar Collectors, and SRCC Standard TM-1, Solar Domestic Hot Water System and Component Test Protocol. Collectors in installed solar water heating systems should meet the following criteria:
 1. Be installed with a tilt angle between 10 degrees and 40 degrees of the horizontal; and
 2. Be installed at an orientation within 45 degrees of true south.
- **R403.5 Mechanical ventilation (Mandatory).** The building shall be provided with ventilation that meets the requirements of the Florida Building Code, Residential or Florida Building Code, Mechanical, as applicable, or with other approved means of ventilation. Outdoor air intakes and exhausts shall have automatic or gravity dampers that close when the ventilation system is not operating.
 - **R403.5.1 Whole-house mechanical ventilation system fan efficacy.** Mechanical ventilation system fans shall meet the efficacy requirements of Table R403.5.1.

Exception: Where mechanical ventilation fans are integral to tested and listed HVAC equipment, they shall be powered by an electronically commutated motor.
 - **R403.5.2 Ventilation air.** Residential buildings designed to be operated at a positive indoor pressure or for mechanical ventilation shall meet the following criteria:
 1. The design air change per hour minimums for residential buildings in ASHRAE 62, Ventilation for Acceptable Indoor Air Quality, shall be the maximum rates allowed for residential applications.
 2. No ventilation or air-conditioned system make air shall be provided to conditioned space from attics, crawlspaces, attached closed garages or outdoor spaces adjacent to swimming pools or spas.
 3. If ventilation air is drawn from enclosed spaces(s), then the walls of the space(s) from which air is drawn shall be insulated to a minimum of R-11 and the ceiling shall be insulated to a minimum of R-19, space permitting, or R-10 otherwise.
- **R403.6 Heating and cooling equipment (Mandatory).** The following sections are mandatory for cooling and heating equipment.
 - **R403.6.1 Equipment sizing.** Heating and cooling equipment shall be sized in accordance with ACCA Manual S based on the equipment loads calculated in accordance with ACCA Manual J or other approved heating and cooling calculation methodologies, based on building loads for the directional orientation of the building. The manufacturer and model number of the outdoor and indoor units (if split system) shall be submitted along with the sensible and total cooling capacities at the design conditions described in Section R302.1. This code does not allow designer safety factors, provisions for future expansion or other factors which affect equipment sizing. System sizing calculations shall not include loads created by local intermittent mechanical ventilation such as standard kitchen and bathroom exhaust systems.
 - **R403.6.1.1 Cooling equipment capacity.** Cooling only equipment shall be selected so that its total capacity is not less than the calculated total load, but not more than 1.15 times greater than the total load calculated according to the procedure selected in Section 403.6, or the closest available size provided by the manufacturer's product lines. The corresponding latent capacity of the equipment shall not be less than the calculated latent load.

MANDATORY REQUIREMENTS - (Continued)

- **R403.6.1.1 Cooling equipment capacity. (continued)** The published value for AHRI total capacity is a nominal, rating-test value and shall not be used for equipment sizing. Manufacturer's expanded performance data shall be used to select cooling-only equipment. This selection shall be used to select cooling-only equipment. This selection shall be based on the outdoor design dry bulb temperature for the load calculation (or entering water temperature for water-source equipment), the blower cfm provided by the expanded performance data, the design value for entering wet bulb temperature and the design value for entering dry bulb temperature.

Design values for entering wet bulb and dry bulb temperature shall be for the indoor dry bulb and relative humidity used for the load calculation and shall be adjusted for return side gains if the return duct(s) is installed in an unconditioned space.

Exceptions:

1. Attached single- and multi-family residential equipment sizing may be selected so that its cooling capacity is less than the calculated total sensible load but not less than 80 percent of that load.
2. When signed and sealed by a Florida-registered engineer, in attached single- and multi-family units, the capacity of equipment may be sized in accordance with good design practice.

○ **R403.6.1.2 Heating equipment capacity**

- **R403.6.1.2.1 Heat pumps.** Heat pumps sizing shall be based on the cooling requirements as calculated according to Section R403.6.1.1 and the heat pump total cooling capacity shall not be more than 1.15 times greater than the design cooling load.
- **R403.6.1.2.2 Electric resistance furnaces.** Electric resistance furnaces shall be sized within 4 kW of the design requirements calculated according to the procedure selected in Section R403.6.1.
- **R403.6.1.2.3 Fossil fuel heating equipment.** The capacity of fossil fuel heating equipment with natural draft atmospheric burners shall not be less than the design load calculated in accordance with Section R403.6.1.

○ **R403.6.1.3 Extra capacity required for special occasions.** Residences requiring excess cooling or heating equipment capacity on an intermittent basis, such as anticipated additional loads caused by major entertainment events, shall have equipment sized or controlled to prevent continuous space cooling or heating within that space by one or more of the following options:

1. A separate cooling or heating system is utilized to provide cooling or heating to the major entertainment areas.
2. A variable capacity system sized for optimum performance during base load periods is utilized.

- **R403.7 Systems serving multiple dwelling units (Mandatory).** Systems serving multiple dwelling units shall comply with Sections C403 and C404 of the Commercial Provisions in lieu of Section R403.

- **R403.8 Snow melt system controls (Mandatory).** Snow and ice-melting systems, supplied through energy service to the building, shall include automatic controls capable of shutting off the system when the pavement temperature is above 55°F, and no precipitation is falling and an automatic or manual control that will allow shut off when the outdoor temperature is above 40°F.

- **R403.9 Swimming pools, inground spas and portable spas (Mandatory).** The energy requirements for residential pools and inground spas shall be as specified in Sections R403.9.1 through R403.9.3 and in accordance with ANSI/APSP-15. The energy requirements for portable spas shall be in accordance with ANSI/APSP-14.

○ **R403.9.1 Pool and spa heaters.** All pool heaters shall be equipped with a readily accessible on-off switch that is mounted outside the heater to allow shutting off the heater without adjusting the thermostat setting.

- **R403.9.1.1 Gas and oil-fired pool and spa heaters.** All gas- and oil-fired pool and space heaters shall have a minimum thermal efficiency of 82 percent for heaters manufactured on or after April 16, 2013 when tested in accordance with ANSI Z 21.56. Pool heaters fired by natural gas or LP gas shall not have continuously burning pilot lights.

- **R403.9.1.2 Heat pump pool heaters.** Heat pump pool heaters shall have a minimum COP of 4.0 when tested in accordance with AHRI 1160, Table 2, Standard Rating Conditions-Low Air Temperature. A test report from an independent laboratory is required to verify procedure compliance. Geothermal swimming pool not required to meet this standard.

○ **R403.9.2 Time switches.** Time switches or other control method that can automatically turn off and on heaters and pumps according to a preset schedule shall be installed on all heaters and pumps. Heaters, pumps and motors that have built in timers shall be deemed in compliance with this equipment.**Exceptions:**

1. Where public health standards require 24-hour pump operations.
2. Where pumps are required to operate solar- and waste-heat-recovery pool heating systems.
3. Where pumps are powered exclusively from on-site renewable generation

○ **R403.9.3 Covers.** Heated swimming pools and inground permanently installed spas shall be equipped with a vapor-retardant cover on or at the water surface or a liquid cover or other means proven to reduce heat loss.

Exception: Outdoor pools deriving over 70 percent of the energy for heating from the site-recovered energy, such as a heat pump or solar energy source computed over an operating season.

- **R404.1 Lighting equipment (Mandatory).** A minimum of 75 percent of the lamps in permanently installed lighting fixtures shall be high-efficacy lamps or a minimum of 75 percent of permanently installed lighting fixtures shall contain only high efficacy lamps.

Exception: Low-voltage lighting shall not be required to utilize high-efficacy lamps.

○ **R404.1.1 Lighting equipment (Mandatory).** Fuel gas lighting systems shall not have continuously burning pilot lights.

- **R405.2 Performance ONLY.** All ducts not entirely inside the building thermal envelope shall be insulated to a minimum of R-6.

○ **R405.2.1 Performance ONLY.** Ceilings shall have minimum insulation of R-19. Where single assembly of the exposed deck and beam type or concrete deck roofs do not have sufficient space, R-10 is allowed.

MANDATORY REQUIREMENTS - (Continued)

o **R403.7.1.1 Cooling equipment capacity. (continued)** Cooling only equipment shall be selected so that its total capacity is not less than the calculated total load but not more than 1.15 times greater than the total load calculated according to the procedure selected in Section 403.7, or the closest available size provided by the manufacturer's product lines. The corresponding latent capacity of the equipment shall not be less than the calculated latent load.

The published value for AHRI total capacity is a nominal, rating-test value and shall not be used for equipment sizing. Manufacturer's expanded performance data shall be used to select cooling-only equipment. This selection shall be based on the outdoor design dry-bulb temperature for the load calculation (or entering water temperature for water-source equipment), the blower CFM provided by the expanded performance data, the design value for entering wet-bulb temperature and the design value for entering dry-bulb temperature.

Design values for entering wet-bulb and dry-bulb temperatures shall be for the indoor dry bulb and relative humidity used for the load calculation and shall be adjusted for return side gains if the return duct(s) is installed in an unconditioned space.

Exceptions:

1. Attached single- and multiple-family residential equipment sizing may be selected so that its cooling capacity is less than the calculated total sensible load but not less than 80 percent of that load.
 2. When signed and sealed by a Florida-registered engineer, in attached single- and multiple-family units, the capacity of equipment may be sized in accordance with good design practice.
- o **R403.7.1.2 Heating equipment capacity.**
- **R403.7.1.2.1 Heat pumps** Heat pump sizing shall be based on the cooling requirements as calculated according to Section R403.7.1.1, and the heat pump total cooling capacity shall not be more than 1.15 times greater than the design cooling load even if the design heating load is 1.15 times greater than the design cooling load.
 - **R403.7.1.2.2 Electric resistance furnaces.** Electric resistance furnaces shall be sized within 4 kW of the design requirements calculated according to the procedure selected in Section R403.7.1.
 - **R403.7.1.2.3 Fossil fuel heating equipment.** The capacity of fossil fuel heating equipment with natural draft atmospheric burners shall not be less than the design load calculated in accordance with Section R403.7.1.
- o **R403.7.1.3 Extra capacity required for special occasions.** Residences requiring excess cooling or heating equipment capacity on an intermittent basis, such as anticipated additional loads caused by major entertainment events, shall have equipment sized or controlled to prevent continuous space cooling or heating within that space by one or more of the following options:
1. A separate cooling or heating system is utilized to provide cooling or heating to the major entertainment areas.
 2. A variable capacity system sized for optimum performance during base load periods is utilized.
- **R403.8 Systems serving multiple dwelling units (Mandatory).** Systems serving multiple dwelling units shall comply with Sections C403 and C404 of the IECC—Commercial Provisions in lieu of Section R403.
- **R403.9 Snow melt and ice system controls (Mandatory).** Snow- and ice-melting systems, supplied through energy service to the building, shall include automatic controls capable of shutting off the system when the pavement temperature is above 50°F (10°C), and no precipitation is falling and an automatic or manual control that will allow shutoff when the outdoor temperature is above 40°F (4.8°C).
- **R403.10 Pools and permanent spa energy consumption (Mandatory).** The energy consumption of pools and permanent spas shall be in accordance with Sections R403.10.1 through R403.10.5.
- o **R403.10.1 Heaters.** The electric power to heaters shall be controlled by a readily accessible on-off switch that is an integral part of the heater mounted on the exterior of the heater, or external to and within 3 feet (914 mm) of the heater. Operation of such switch shall not change the setting of the heater thermostat. Such switches shall be in addition to a circuit breaker for the power to the heater. Gas-fired heaters shall not be equipped with continuously burning ignition pilots.
- o **R403.10.2 Time switches.** Time switches or other control methods that can automatically turn off and on according to a preset schedule shall be installed for heaters and pump motors. Heaters and pump motors that have built-in time switches shall be in compliance with this section.
- Exceptions:
1. Where public health standards require 24-hour pump operations.
 2. Pumps that operate solar- and waste-heat-recovery pool heating systems.
 3. Where pumps are powered exclusively from on-site renewable generation.
- o **R403.10.3 Covers.** Outdoor heated swimming pools and outdoor permanent spas shall be equipped with a vapor-retardant cover on or at the water surface or a liquid cover or other means proven to reduce heat loss.
- Exception: Where more than 70 percent of the energy for heating, computed over an operation season, is from site-recovered energy, such as from a heat pump or solar energy source, covers or other vapor-retardant means shall not be required.
- o **R403.10.4 Gas- and oil-fired pool and spa heaters.** All gas- and oil-fired pool and spa heaters shall have a minimum thermal efficiency of 82 percent for heaters manufactured on or after April 16, 2013, when tested in accordance with ANSI Z 21.56. Pool heaters fired by natural or LP gas shall not have continuously burning pilot lights.

o **R403.10.5 Heat pump pool heaters.** Heat pump pool heaters shall have a minimum COP of 4.0 when tested in accordance with AHRI 1160, Table 2, Standard Rating Conditions-Low Air Temperature. A test report from an independent laboratory is required to verify procedure compliance. Geothermal swimming pool heat pumps are not required to meet this standard.

- **R403.11 Portable spas (Mandatory).** The energy consumption of electric-powered portable spas shall be controlled by the requirements of APSP-14.

Section R404

ELECTRICAL POWER AND LIGHTING SYSTEMS

- **R404.1 Lighting equipment (Mandatory).** Not less than 75 percent of the lamps in permanently installed lighting fixtures shall be high-efficacy lamps or not less than 75 percent of the permanently installed lighting fixtures shall contain only high-efficacy lamps.
 - o **Exception:** Low-voltage lighting.
 - o **R404.1.1 Lighting equipment (Mandatory).** Fuel gas lighting systems shall not have continuously burning pilot lights.

TABLE 402.4.1.1

AIR BARRIER AND INSULATION INSPECTION COMPONENT CRITERIA

Project Name: Right-Energy® Florida 2014 Example		Builder Name: Wrightsoft
Street: 1516 Ninth Street		Permit Office: Tampa
City, State, Zip: Tampa, FL 33601		Permit Number: 2222-1
Owner: Mr. and Mrs. Henry Wagner		Jurisdiction: Hillsborough County
Design Location: FL, Tampa International AP		
COMPONENT	AIR BARRIER CRITERIA	INSULATION INSTALLATION CRITERIA
General requirements	A continuous air barrier shall be installed in the building envelope. Exterior thermal envelope contains a continuous barrier. Breaks or joints in the air barrier shall be sealed.	Air-permeable insulation shall not be used as a sealing material.
Ceiling/attic	The air barrier in any dropped ceiling/soffit shall be aligned with the insulation and any gaps in the air barrier shall be sealed. Access openings, drop down stairs or knee wall doors to unconditioned attics paces shall be sealed.	The insulation in any dropped ceiling/soffit shall be aligned with the air barrier.
Walls	The junction of the foundation and sill plate shall be sealed. The junction of the top plate and the top of exterior walls shall be sealed. Knee walls shall be sealed.	Cavities with corners and headers of frame walls shall be insulated by completely filling the cavity with a material having a thermal resistance of R-3 per inch minimum. Exterior thermal envelope insulation for framed walls shall be installed in substantial contact and continuous alignment with the air barrier
Windows, skylights and doors	The space between window/door jambs and framing, and skylights and framing shall be sealed.	
Rim joists	Rim joists are insulated and include an air barrier.	Rim joists shall be insulated.
Floors (including above-garage and cantilevered floors)	The air barrier shall be installed at any exposed edge of insulation.	Floor framing cavity Insulation shall be (installed to maintain permanent contact with the underside of subfloor decking, of floor framing cavity insulation shall be permitted to be in contact with the top side of sheathing, or continuous insulation installed on the underside of floor framing and extends from the bottom to the top of all perimeter floor framing members.
Crawl space walls	Exposed earth in unvented crawl spaces shall be covered with a Class I vapor retarder with overlapping joints taped.	Where provided in lieu of floor insulation, insulation shall be permanently attached to the crawlspace walls.
Shafts, penetrations	Duct shafts, utility penetrations, and flue shaft openings to exterior or unconditioned space shall be sealed.	
Narrow cavities		Batts in narrow cavities shall be cut to fit, or narrow cavities shall be filled by insulation that on installation readily conforms to the available cavity spaces.
Garage separation	Air sealing shall be provided between the garage and conditioned spaces.	
Recessed lighting	Recessed light fixtures installed in the building thermal envelope shall be sealed to the drywall.	Recessed light fixtures installed in the building thermal envelope shall be air tight and IC rated.
Plumbing and wiring		Batt insulation shall be cut neatly to fit around wiring and plumbing in exterior walls, or insulation that on installation readily conforms to available space shall extend behind piping and wiring.
Shower/tub on exterior wall	The air barrier shall be installed behind electrical or communication boxes or air-sealed boxes shall be installed.	Exterior walls adjacent to showers and tubs shall be insulated.
Electrical/phone box on exterior walls	The air barrier shall be installed behind electrical or communication boxes or air-sealed boxes shall be installed.	
HVAC register boots	HVAC register boots that penetrate building thermal envelope shall be sealed to the subfloor or drywall.	
Concealed sprinklers	When required to be sealed, concealed fire sprinklers shall only be sealed in a manner that is recommended by the manufacturer. Caulking or other adhesive sealants shall not be used to fill voids between fire sprinkler cover plates and walls or ceilings.	

FLORIDA ENERGY EFFICIENCY CODE FOR BUILDING CONSTRUCTION

Envelope Leakage Test Report Performance Methods

Project Name: Right-Energy® Florida 2014 Example Street: 1516 Ninth Street City, State, Zip: Tampa, FL 33601 Design Location: FL, Tampa International AP Cond. Floor Area: 2100 ft ²	Builder Name: Wrightsoft Permit Office: Tampa Permit Number: 2222-1 Jurisdiction: Hillsborough County Cond. Volume: 18900 ft ³
---	---

Envelope Leakage Test Results

Regression Data:

C: _____ n: _____ R: _____

Single or Multi Point Test Data:

	HOUSE PRESSURE	Pa	FLOW	cfm
1		Pa		cfm
2		Pa		cfm
3		Pa		cfm
4		Pa		cfm
5		Pa		cfm
6		Pa		cfm

Leakage Characteristics

Required ACH(50) from

FORM R405-2017: _____

Tested ACH(50)*: _____

* Tested leakage must be less than or equal to the required ACH(50) shown on Form R405-2017 for this building. If the tested ACH(50) is less than 3, the building must have a mechanical ventilation system.

402.4.1.2 Testing option. The building or dwelling unit shall be tested and verified as having an air leakage rate of not exceeding 7 air changes per hour in Climate Zones 1 and 2. Testing shall be conducted with a blower door at a pressure of 0.2 inches w.g. (50 Pascals). Testing shall be conducted by either individuals as defined in Section 553.993(5) or (7), Florida Statutes or individuals licensed as set forth in Section 489.105(3)(f), (g), or (i) or an approved third party. A written report of the results of the test shall be signed by the party conducting the test and provided to the code official. Testing shall be performed at any time after creation of all penetrations of the building thermal envelope.

During testing:

1. Exterior windows and doors, fireplace and stove doors shall be closed, but not sealed, beyond the intended weatherstripping or other infiltration control measures;
2. Dampers including exhaust, intake, makeup air, backdraft and flue dampers shall be closed, but not sealed beyond intended infiltration control measures;
3. Interior doors, if installed at the time of the test, shall be open;
4. Exterior doors for continuous ventilation systems and heat recovery ventilators shall be closed and sealed;
5. Heating and cooling systems, if installed at the time of the test, shall be turned off; and
6. Supply and return registers, if installed at the time of the test, shall be fully open.


I hereby certify that the above envelope leakage performance results demonstrate compliance with Florida Energy Code requirements in accordance with Section R402.4.1.2.

Signature: _____

Printed Name: _____

DATE: _____

Testing shall be conducted by either individuals as defined in Section 553.993(5) or (7), Florida Statutes or individuals licensed as set forth in Section 489.105(3)(f), (g), or (i) or an approved third party. A written report of the results of the test shall be signed by the party conducting the test and provided to the code official.



BUILDING OFFICIAL: _____

DATE: _____

FLORIDA ENERGY EFFICIENCY CODE FOR BUILDING CONSTRUCTION

Form R405 Duct Leakage Test Report Performance Method

Project Name: Right-Energy® Florida 2014 Example Street: 1516 Ninth Street City, State, Zip: Tampa, FL 33601 Design Location: FL, Tampa International AP	Builder: Wrightsoft Permit Office: Tampa Permit Number: 2222-1 Jurisdiction: Hillsborough County Duct Test Time: Post Construction
---	--

Required Duct Leakage from FORM R405-2017 _____ Qn (Out)

Duct Leakage Test Results

CFM25 Duct Leakage Test Values		
Line	System	Outside Duct Leakage
1	System 1	_____ cfm25(Out)
2	System 2	_____ cfm25(Out)
3	System 3	_____ cfm25(Out)
4	System 4	_____ cfm25(Out)
5	Tested Total House Duct System Leakage	Sum lines 1-4 _____ Divide by _____ (Total Conditioned Floor Area) = _____ Qn (Out)*

*Tested Qn (Out) must be less than or equal to the required Qn (Out)

I certify the above tested leakage to outside, Qn, is not greater than the proposed duct leakage Qn specified on FORM R405-2017.

Signature: _____

Printed Name: _____

DATE: _____

Duct tightness shall be verified by testing to ANSI/RESNET/ICC 380 by either individuals as defined in Section 553.993(5) or (7), Florida Statutes, or individuals licensed as set forth in Section 489.105(3)(f), (g), or (i), Florida Statutes.



BUILDING OFFICIAL: _____

DATE: _____

Reference Home Characteristics

Mr. and Mrs. Henry Wagner
1516 Ninth Street
Tampa, FL 33601

Title: SimpleHouse
FLBase2014

TMY City: FL_Tampa_Intl_AP

Above-grade Walls (Uo)	0.084
Above-grade Wall Solar Absorptance	0.75
Above-grade Wall Infrared Emittance	0.90
Basement Walls (Uo)	n/a
Above-grade Floors (Uo)	n/a
Slab Insulation R-Value	0.0
Ceilings (Uo)	0.030
Roof Solar Absorptance	0.75
Roof Infrared Emittance	0.90
Attic Vent Area (ft ²)	7.00
Crawlspace Vent Area (ft ²)	n/a
Exposed Masonry Floor Area (ft ²)	508.00
Carpet & Pad R-Value	2.0
Door Area (ft ²)	40.00
Door U-Factor	0.400
North Window Area (ft ²)	78.75
South Window Area (ft ²)	78.75
East Window Area (ft ²)	78.75
West Window Area (ft ²)	78.75
Window U-Factor	0.400
Window SHGC (Heating)	0.2169
Window SHGC (Cooling)	0.2169
ACH50	7.00
Internal Gains * (Btu/day)	80192
Water heater gallons per day	60.00
Water Heater set point temperature	120.00
Water heater efficiency rating	0.95
Labeled Heating System Rating and Efficiency	HSPF = 8.2
Labeled Cooling System Rating and Efficiency	SEER = 14.0
Air Distribution System Efficiency	0.88
Thermostat Type	Manual
Heating Thermostat Settings	72.0 (All hours)
Cooling Thermostat Settings	75.0 (All hours)