

FLORIDA ENERGY EFFICIENCY CODE FOR BUILDING CONSTRUCTION

Air Distribution System Test Report

Project Name: Sample Addition	Builder Name: BUILDER
Street: 346 Main Street	Permit Office:
City, State, Zip: Orlando , FL , 32922-	Permit Number:
Owner: OWNER	Jurisdiction:
Design Location: FL, Orlando	

Air Distribution System Leakage Test Results

CFM25 Air Distribution System Leakage Test Values		
Line	System	Duct Leakage to Outdoors
1	System 1	_____cfm25(out)
2	System 2	_____cfm25(out)
3	System 3	_____cfm25(out)
4	System 4	_____cfm25(out)
5	Total House Duct System Leakage	Sum lines 1-4 _____ Divide by _____ (Total Conditioned Floor Area) = _____ (Q_{n,out}) To qualify as "substantially leak free" Q _{n,out} must be less than or equal to 0.03.

I hereby certify that the above duct testing performance results demonstrate compliance with the Florida Energy Code requirements in accordance with Section 403.2.2.1.

Signature: _____

Printed Name: _____

Florida Rater Certification #: _____

DATE: _____

Florida Building Code requires that testing to confirm duct leakage be performed by a Class 1 Florida Energy Gauge Certified Energy Rater. Certified Florida Class 1 raters can be found at:
<http://energygauge.com/search.htm>



BUILDING OFFICIAL: _____

DATE: _____