

Florida Building Commission
December 12, 2017
Legal Report

HUTCHINSON ISLAND MARRIOTT
555 NE OCEAN BOULEVARD
STUART, FLORIDA 34996

SWIMMING POOL TECHNICAL ADVISORY COMMITTEE (TAC)

DS 2017-070 by John (JC) Centera of Aquatic Design Services, LLC

Question: Is the grout line allowed to be included in the measurement of a 1”x 1” tile installed on a commercial pool per section 454.1.2.1, when the tile is sold and distributed as 1” x 1”?

Answer: Yes, as per the definition of the term “Nominal” of section 202 of the 2014 FBC, Building and the 2017 FBC, Building, the grout line can be included when meeting the 1”x 1” tile requirements set forth in section 454.1.2.1 if the tile is sold and distributed as 1”x 1” nominal or trade size tile.

PRODUCT APPROVAL PROGRAM OVERSIGHT COMMITTEE (POC)

DS 2017-072 by Chris Birchfield of Global Fireproof Solutions, Inc.

Question 1: Do the products listed above fall within the scope of Rule61G20-3?

Answer: No, the products in question are not elements of the building envelope or structural frame and, therefore, fall outside of the scope of the state product approval pursuant to Rule 61G20-3, F.A.C. However, the products in question are subject to review and approval at the local level.