

FLORIDA BUILDING COMMISSION
Mechanical Technical Advisory Committee
Orlando, Florida
August 12, 2002
REPORT

Voting Members Present:

Peggy Patterson, Steve Bassett, MikeMcCombs, Phillip Simmons, Pete Quintela, Don Pittman, Bob Andrews, Betsy Goll, Jim Cummings, Leonard Lipka

Meeting Objectives:

1. Approve minutes and agenda.
2. Consider 19 proposed “Glitch” modifications to the Florida Building Code, Mechanical.

ACTIONS TAKEN:

The TAC considered 19 proposed code modifications and provided recommendations to the Commission for consideration.

OTHER BUSINESS:

The TAC was asked to consider the criteria of section 604.7 of the mechanical code on duct identification. It seems that t2” duct board products do not have the labeling required by this section as they are often used in conjunction with product covers as well as for other functions than duct manufacture. The TAC found that the requirements of 604.7 held and put the manufacturers on notice to that effect.

The meeting was adjourned at 4:15 p.m.