

UL 1995 Transition to UL 60335-2-40



JULY 31
2019

Existing products impacted by, but do not yet comply with the new Electric Heat Back-up Protection requirements or the Ultraviolet Light (UV) requirements noted in UL 1995, 5th edition must be evaluated for compliance

UL 60335-2-40 3rd edition is out for ballot. This edition contains A2L refrigerant specific requirements. The scope now aligns with UL 1995

DECEMBER
2018

SEPTEMBER 15
2017

UL 60335-2-40, 2nd edition published

- Includes requirements for air-conditioners rated up to 15kV, partial units, and revised electric heat requirements.
- Includes requirements for the use of A2 and A3 (flammable) refrigerants.

NOVEMBER 30
2012

UL 60335-2-40, 1st edition published

- Covers products rated less than 600 Volts.
- Does not include requirements for the use of A2 and A3 (flammable) refrigerants.

Currently, manufacturers may have UL 1995 Certified products evaluated to UL 60335-2-40. UL 1995 will remain a valid certification standard through January 1, 2024, when it will be effectively obsolete. At that time, UL 1995 will no longer be used to certify new products.

FEBRUARY 6
2019

60335-2-40 ballot closes

JULY 15
2015

UL 1995, 5th edition published
The 5th Edition covers all products..

JANUARY 1
2024

All products shall comply with UL 60335-2-40 3rd edition by January 1, 2024. Today, products may be listed to either UL 1995 or UL 60335-2-40. However, with minimum equipment efficiency changes scheduled for 2023 and 2024, coupled with Low GWP refrigerant requirements expected in several states, all equipment within the scope of UL 1995 shall be retested to the requirements in the 3rd edition UL 60335-2-40

Empowering Trust™