Madani, Mo

From:

Michael Weinbaum <michael@martinaquatic.com>

Sent:

Thursday, January 2, 2020 4:43 PM

To:

Madani, Mo

Subject:

Comments on section 454 integration

Mo-

I received the integration first draft from Dallas Thiesen on the 17th of December.

I see an error in 454.1.1.1, SW7259 that I've corrected with a blue line: 454.1.1.1 Sizing. The bathing load for conventional swimming pools, wading pools, interactive water features, water activity pools and special purpose pools shall be computed either on the basis of one person per 5 gpm (0.32 L/s) of recirculation flow, or one person per each 20 square feet (0.9 m²) of surface area, whichever is less. The bathing load for spa type pools shall be based on one person per each 10 square feet) 0.9m²) of surface area and 3/4 gpm (0.04 L/s) at nontransient facilities. The pools provided at a transient facility shall be able to accommodate one bather per five living units. while the bathing load at a non-transient facility shall be at least one bather per seven living units. Recreational vehicle sites, campsites and boat slips designated for live-aboards shall be considered a transient living unit. For properties with multiple pools, this requirement includes the cumulative total bathing load of all swimming pools, spas, wading pools and interactive water features. All other types of projects shall be

Also, please see my previous e-mail about SW 7819. I'm sorry if the subject line on that one was confusing.



MIKE WEINBAUM, P.E.

Senior Engineer
Martin Aquatic Design & Engineering

T: 407.598.0468 M: 813.628.4146

E: michael@martinaguatic.com

Web · Blog · LinkedIn