

Florida has a broad public records law and all correspondence, including email addresses, may be subject to disclosure.

----- Forwarded by Mo Madani/DCA/FLEOC on 03/10/2008 03:58 PM -----

"Chris Schulte" <chris@latite.com>

02/11/2008 09:10 AM

T
o

c
c

S
u
b
j
e
c
t

<mo.madani@dca.state.fl.us>

FW: Wind Mitigation Report

Mo, one of the changes I suggested & was agreed to was titling of chart 201.2...it doesn't appear as though the change went in correctly..."spacing" was added to column one...it should have been added to columns 3 & 4 instead...drop it off column one. Column 3 should read: Wind speed 110 mph or less supplemental fastener spacing shall be no greater than..."spacing" should be added to column 4 in the same respect....

-----Original Message-----

From: Jeff Blair [<mailto:jblair@fsu.edu>]

Sent: Friday, February 08, 2008 3:19 PM

To: Jim Carducci; Billy Cone; Rick Dixon; Bill Dumbaugh; Burt Logan; Mo Madani; Tim Reinhold; Richard Reynolds; Jim Schock; Chris Schulte; Eric Stafford

Cc: Betty Stevens

Subject: Wind Mitigation Report