

**TABLE 1017.2 EXIT ACCESS TRAVEL DISTANCE<sup>a</sup>**

OCCUPANCY	WITHOUT SPRINKLER SYSTEM (feet)	WITH SPRINKLER SYSTEM (feet)
A, E, F-1, M, R, S-1	200	250b
I-1	Not Permitted	250b
B	200	300c
F-2, S-2, U	300	400c
H-1	Not Permitted	75d
H-2	Not Permitted	100d
H-3	Not Permitted	150d
H-4	Not Permitted	175d
H-5	Not Permitted	200c
I-2, I-3, I-4	Not Permitted <sup>e</sup>	200c
S-1	200	400b

For SI: 1 foot = 304.8 mm.

See the following sections for modifications to *exit access* travel distance requirements:

- Section 402.8: For the distance limitation in malls.
- Section 404.9: For the distance limitation through an atrium space.
- Section 407.4: For the distance limitation in Group I-2.
- Sections 408.6.1 and 408.8.1: For the distance limitations in Group I-3.
- Section 411.4: For the distance limitation in special amusement buildings.
- Section 412.7: For the distance limitations in aircraft manufacturing facilities.
- Section 1006.2.2.2: For the distance limitation in refrigeration machinery rooms.
- Section 1006.2.2.3: For the distance limitation in refrigerated rooms and spaces.
- Section 1006.3.3: For buildings with one exit.**
- Section 1017.2.2: For increased distance limitation in Groups F-1 and S-1.
- Section 1029.7: For increased limitation in assembly seating.
- Section 3103.4: For temporary structures.
- Section 3104.9: For pedestrian walkways.

Buildings equipped throughout with an *automatic sprinkler system* in accordance with Section 903.3.1.1 or 903.3.1.2. See Section 903 for occupancies where *automatic sprinkler systems* are permitted in accordance with Section 903.3.1.2.

Buildings equipped throughout with an *automatic sprinkler system* in accordance with Section 903.3.1.1.

Group H occupancies equipped throughout with an *automatic sprinkler system* in accordance with Section 903.2.5.1.

Group I-4 day care facilities for which an automatic sprinkler system is not required in accordance with Section 903.2.6, exception 2.