

From: Michael Nappa <michael.a.nappa@gmail.com>
Sent: Saturday, July 18, 2026 12:01 AM
To: Madani, Mo <Mo.Madani@myfloridalicense.com>
Subject: Pool NEC electrical code for bonding -support TIA

[NOTICE] This message comes from a system outside of DBPR. Please exercise caution when clicking on links and/or providing sensitive information. If you have concerns, please contact your Knowledge Champion or the DBPR Helpdesk.

Hi Mr. Madani,

I support TIA to say that single wire conductor is not sufficient for equipotential, and that the copper mesh be used. I live in NJ and have had experience in bonding since I was having stray voltage / mild shock issues from concrete decking to the water surface in my pool.

Please email me back if you have any questions. I wanted you to get this email by August so it can count towards the specific endeavor to change the building code in Florida. I support improvement of more than just a single wire buried in concrete decking.

Thank you.
-Mike Nappa