

Mr. Madani,

I believe there is a typographical error in Section 1506.5 (page 192) of the FBC Supplement currently out for public review. (Attached) I believe that the 300 foot limit introduced in this section is supposed to be 3,000 feet as marked in **bold red** below. This is supported by the fact that 914 meters is indeed 3,000 feet.

Bob

1506.5 Nails. Nails shall be corrosion-resistant nails conforming to ASTM F1667 or an equal corrosion resistance by coating, electro galvanization, mechanical galvanization, hot dipped galvanization, stainless steel, nonferrous metal and alloys or other suitable corrosion-resistant material, or corrosion resistance shall be demonstrated in accordance with TAS114, Appendix E. In areas within **3,000** feet (914 m) of a saltwater coastline, nails shall comply with Section 1711.

Robert A. Zabcik, P.E. (Texas), LEED AP
Technical Director



281.229.9146 • www.metalconstruction.org
Follow us: [Facebook](#) | [LinkedIn](#) | [Blog](#)