



Electrical

TECHNICAL ADVISORY COMMITTEE

All Mods

Total Mods for this report: 6

TAC Recommendation Pending Review

TAC: Electrical 6 Total Mods for Electrical in Pending Review

↳ SubCode: Building

27-Electrical

Mod #	Proponent	Chapter	Section
11060	Mo Madani	27	2703.1
CC # G176-21			

Summary
Requirements pertaining to Lightning Protection Systems are not currently found within the building code. This code change does not require the installation of lightning protection systems, but simply provides guidance to those that are installing lightning protection.

Pending Review

TAC Action

AS
 AS/IC
 D

 D/IC

Staff Classification

Correlates Directly

Deny / discriminates against products and is anti-competative Castronovo / Schock 7 Yes – 1 No Passes

35-Referenced Standards

Mod #	Proponent	Chapter	Section
11673	Mo Madani	35	35
CC # ADM52-22			

Summary
Modification lists the updated standards in the IBC.

Pending Review

TAC Action

AS
 AS/IC
 D

 D/IC

Staff Classification

Correlates Directly

Approve As Submitted Gerwig / Holland 8 Yes – 0 No

2708-Sians

Mod #	Proponent	Chapter	Section
10956	Mo Madani	2708	116.1
CC # G14-22			

Summary
NFPA 70 Section 600.3 requires electric signs to be listed and labeled. This proposal clarifies that electric signs as an assembly are to be listed and labeled to UL 48, and to be installed in accordance with the manufacturers installation instructions.

Pending Review

TAC Action

AS
 AS/IC
 D

 D/IC

Staff Classification

Overlap

Deny / Alreaedy in the NEC and Overlap Wildermuth / Gerwig 8 Yes – 0 No

↳ SubCode: Existing Building



Electrical

TECHNICAL ADVISORY COMMITTEE

All Mods

Total Mods for this report: 6

TAC: Electrical 6 Total Mods for Electrical in Pending Review

4-Repairs

Mod #	Proponent	Chapter	Section	Summary
10689	Mo Madani	4	406.1	This proposal is intended to update the requirements in the IEBC to match that of the current edition of NFPA 70 the NEC
<u>CC #</u> EB43-22				

Pending Review

TAC Action

AS AS/IC D

D/IC

Staff Classification

Correlates Directly

Approve As Submitted / Consistent with NFPA 99 Territo / Holland 6 Yes – 2 No
Gerwig – approving this could create a conflict.

SubCode: Residential

3-Building Planning

Mod #	Proponent	Chapter	Section	Summary
11422	Mo Madani	3	309.6	Adds new Section R309.6 "Electric vehicle charging systems.". Adds new reference standards UL 2202-2009 and UL 2594-2016.
<u>CC #</u> RB88-22				

Pending Review

TAC Action

AS AS/IC D

D/IC

Staff Classification

Correlates Directly

Approve As Submitted / this is an NEC issue Hall / Castronovo 6 Yes – 0 No
Gerwig this should not be in this section but in electrical section. Already info in NEC that addresses this issue.
Holland – this is not final draft and should disregard monograph.

Mod #	Proponent	Chapter	Section	Summary
11486	Mo Madani	3	328.1	Proposal intended to clarify what the product marking actually is. To align with the wording that will ultimately be in the standard. Concerning Energy storage systems.
<u>CC #</u> RB158-22				

Pending Review

TAC Action

AS AS/IC D

D/IC

Staff Classification

Correlates Directly

Approve As Submitted Holland / Gerwig 5 Yes – 3 No Fails
Holland -this aligns IRC with Standard 855 -
Hall – lithium batteries should not be stored inside habitable spaces due to hazards.
Castronovo – should not be stored inside habitable spaces. Mo – staff to assist to help avoid conflict.



Electrical

TECHNICAL ADVISORY COMMITTEE

All Mods

Total Mods for this report: 6

Modification #: ALL
Code Change Cycle: 2026 ICC Code Change Original Modification
Chapter & Topic: ALL
Date Submitted From: ALL
TAC: E
Commission Action: ALL
Proponent Last Name: ALL
Text of Modification: ALL
Affects HVHZ: ALL

Code Version: 2026
Sub Code: ALL
Section: ALL
Date Submitted To: ALL
TAC Recommendation: ALL
Modification Status: Verified
Proponent First Name: ALL
Related Modifications: ALL
Archived: No