



Plumbing
TECHNICAL ADVISORY COMMITTEE

All Mods

Total Mods for this report: 101

TAC Recommendation Pending Review

TAC: Plumbing **101** Total Mods for **Plumbing** in **Pending Review**

↳ **SubCode: Building**

2-Definitions

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10927	Mo Madani	2	202	Adds new definition "[BG] AMBULATORY CARE FACILITY". The intent is to not appear to have two different types of 'ambulatory care facilities'.

CC #
G3-21 Part III

Pending Review TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification
Correlates Directly

Approve As Submitted / Editorial Shilling / Duran 9 Yes – 0 No

4-Special Detailed Requirements Based on Use and Occupancy

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10919	Mo Madani	4	403.11.7	Term 'accessible' is understood as requiring access for persons with disabilities we are making the changes to delete the word accessible from the remaining codes and replace it with defined terms or phrases that are not attributed to requiring access for the physically disabled.

CC #
G1-21 Part III

Pending Review TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification
Correlates Directly

Approve As Submitted / Clarifies the code. Schilling / Gonzalez 9 Yes – 0 No

10-Means of Egress

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11029	Mo Madani	10	1005	This is several proposals across multiple codes and standards to propose requirements appropriate to the unique characteristics of facilities housing computer rooms and data centers or Information technology equipment (ITE)

CC #
G99-21 Part VI

Pending Review TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification
Correlates Directly

Approve As Submitted / Enhances the Code Batts / Kozan 0 Yes – 0 No



Plumbing

TECHNICAL ADVISORY COMMITTEE

All Mods

Total Mods for this report: 101

TAC: Plumbing **101** Total Mods for **Plumbing** in **Pending Review**

12-Interior Environment

Mod #	Proponent	Chapter	Section	Summary
10920	Mo Madani	12	1210.2.2	Term 'accessible' is understood as requiring access for persons with disabilities we are making the changes to delete the word accessible from the remaining codes and replace it with defined terms or phrases that are not attributed to requiring access for the physically disabled.
CC # G1-21 Part IV				

Pending Review TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification
Correlates Directly

Approve as Submitted / Clarifies the code. Schilling / Duren 9 Yes / 0 No

Mod #	Proponent	Chapter	Section	Summary
11637	Mo Madani	12	1210.3.2	seeks to maintain issues pertaining to the interior environment of toilet facilities in Chapter 12 and to streamline Section 2902 to include only those requirements that address the calculation and the distribution of the number and type of plumbing fixtures required
CC # P24-21 Part II				

Pending Review

TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification
Overlap

Deny / Overlap Gonzalez / Duren 9 Yes – 0 No

35-Referenced Standards

Mod #	Proponent	Chapter	Section	Summary
11673	Mo Madani	35	35	Modification lists the updated standards in the IBC.
CC # ADM52-22				

Pending Review TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification
Correlates Directly

Approve As Submitted / Includes relevant standards Schilling / Gonzalez 9 Yes – 0 No



Plumbing

TECHNICAL ADVISORY COMMITTEE

All Mods

Total Mods for this report: 101

TAC: Plumbing **101** Total Mods for **Plumbing** in **Pending Review**

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11635	Mo Madani	2	202	The proposed revision to the definitions for "Listed" recognizes that listing organizations may use other terms to identify "listed" equipment, products, or materials.
<u>CC #</u> ADM1-22 Part I				
Approve As Submitted / adds the word 'listed' Schilling / Gonzalez 9 Yes – 0 No				

Pending Review
TAC Action

AS AS/IC D

D/IC

Staff Classification
Correlates Directly

3-General Regulations

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11652	Mo Madani	3	306.1	Because the term 'accessible' is most commonly understood as requiring access for persons with disabilities we are making the changes to delete the word accessible from the remaining codes and replace it with other words,
<u>CC #</u> G1-21 Part V				
Approve As Submitted / clarifies the code Schilling / Duren 9 Yes – 0 No				

Pending Review
TAC Action

AS AS/IC D

D/IC

Staff Classification
Correlates Directly

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11653	Mo Madani	3	302.6	This proposal sets uniform requirements for field modifications to cold-formed steel framing members (cutting, notching, and boring holes) in accordance with AISI standards.
<u>CC #</u> S196-22				
Approve As Submitted / enhances the code McStravic / Batts 9 Yes – 0 No				

Pending Review
TAC Action

AS AS/IC D

D/IC

Staff Classification
Correlates Directly

Plumbing

TECHNICAL ADVISORY COMMITTEE

All Mods

Total Mods for this report: 101

TAC: Plumbing **101** Total Mods for **Plumbing** in **Pending Review**

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11654	Mo Madani	3	302.3	This proposal consolidates similar wood cutting, notching and boring criteria from the IFGC, IMC, IPC, and IBC into a single location in the IBC, and does not impose new requirements or restrict any practices currently allowed within the I-Codes
<u>CC #</u> S224-22				

Pending Review

TAC Action

AS AS/IC D
 D/IC

Staff Classification

Correlates Directly

This is a two part modification.

Deny part 1 and keep it in the individual Code books. McStraivck / Nutter 8 Yes – 1 No

Part 2 – Motion to Approve As Submitted / enhances the code McStravick / Batts 9 Yes – 0 No

4-Gas Piping Installations				
<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11648	Mo Madani	4	407.2	Modifies text of Section 407.2 Design and installation.
<u>CC #</u> FG3-21				

Pending Review

TAC Action

AS AS/IC D
 D/IC

Staff Classification

Correlates Directly

This is a two part modification.

Part 1 – Approve As Submitted./ Clarifies the code. Schilling / Kozan 9 Yes – 0 No

Part 2 – Approve As Submitted / Consistent with Fuel Gas Code Schilling / Languille 9 Yes – 0 No

3004-Recommended Procedure for Safety Inspection of an Existing Application				
<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11650	Mo Madani	3004	103	Modifies text of SECTION D103 GAS PIPING AND CONNECTIONS INSPECTIONS.
<u>CC #</u> FG8-21				

Pending Review

TAC Action

AS AS/IC D
 D/IC

Staff Classification

Correlates Directly

Approve As Submitted / Clarifies the code. Schilling / Languille 9 Yes – 0 No



Plumbing

TECHNICAL ADVISORY COMMITTEE

All Mods

Total Mods for this report: 101

TAC: Plumbing **101** Total Mods for **Plumbing** in **Pending Review**

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>	Pending Review
10884	Mo Madani	2	202	Adds language for "service Sink"	TAC Action <input type="checkbox"/> AS <input type="checkbox"/> AS/IC <input checked="" type="checkbox"/> D <input type="checkbox"/> D/IC Staff Classification Overlap
CC # P4-21	Deny / Overlap Kozan / Duren 9 Yes – 0 No				

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>	Pending Review
10885	Mo Madani	2	202	Adds clarifying language and definitions for toilet facilities	TAC Action <input checked="" type="checkbox"/> AS <input type="checkbox"/> AS/IC <input type="checkbox"/> D <input type="checkbox"/> D/IC Staff Classification Correlates Directly
CC # P5-21 Part I	This is a two part modification. Part 1 - Approve As Submitted / clarifies the code. Kozan/ Nutter 9 Yes – 0 No Part 2 – Approve As Submitted / consistency in terminology Kozan / Nutter 9 Yes – 0 No				

3-General Regulations					Pending Review
<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>	TAC Action
10886	Mo Madani	3	305.6	Adds language for protection from drywall screws	<input type="checkbox"/> AS <input type="checkbox"/> AS/IC <input checked="" type="checkbox"/> D <input type="checkbox"/> D/IC Staff Classification Correlates Directly
CC # P6-21 Part I	Approve As Submitted / Schilling / McStravic 1 Yes – 8 No Fails				



Plumbing

TECHNICAL ADVISORY COMMITTEE

All Mods

Total Mods for this report: 101

TAC: Plumbing **101** Total Mods for **Plumbing** in **Pending Review**

Mod #	Proponent	Chapter	Section	Summary
10889	Mo Madani	3	305.8	Adds requirements for expansive soil piping
<u>CC #</u> P8-21				
Approve As Submitted / Enhances the code Mayfield / Batts 9 Yes – 0 No				

Pending Review

TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification
Correlates Directly

Mod #	Proponent	Chapter	Section	Summary
10890	Mo Madani	3	306.2.4	Adds language for tracer wire
<u>CC #</u> P9-21				
Deny / unnecessary Kozan / Duren 9 Yes – 0 No There are cameras and other technology that provides more information than this old process.				

Pending Review

TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification
Correlates Directly

Mod #	Proponent	Chapter	Section	Summary
10897	Mo Madani	3	308.5	Removes requirement for brass pipe from Table 308.5
<u>CC #</u> P10-21				
Approve As Submitted / Enhances the code. Batts / McStravic 9 Yes – 0 No				

Pending Review

TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification
Correlates Directly



Plumbing

TECHNICAL ADVISORY COMMITTEE

All Mods

Total Mods for this report: 101

TAC: Plumbing **101** Total Mods for **Plumbing** in **Pending Review**

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10899	Mo Madani	3	311.1	Adds reference standard requirements f ANSI/CAN/IAPMO/ISO 30500
<u>CC #</u> P13-21				
Approve As Submitted / Keeps up with technology and updates standars Nutter / Kozan 9 Yes – 0 No				

Pending Review
TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification
Correlates Directly

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10901	Mo Madani	3	312.4	Adds new language for drainage and vent vacuum test
<u>CC #</u> P14-21				
Approve As Submitted / Enhances the code. Duren / Batts 9 Yes – 0 No				

Pending Review
TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification
Correlates Directly

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10924	Mo Madani	3	310	implements a consistent use of the term "toilet facility"
<u>CC #</u> P28-21				
Approve As Submitted / clarification to the code. Gonzalez / Batts 9 Yes – 0 No				

Pending Review
TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification
Correlates Directly



Plumbing

TECHNICAL ADVISORY COMMITTEE

All Mods

Total Mods for this report: 101

TAC: Plumbing **101** Total Mods for **Plumbing** in **Pending Review**

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11086	Mo Madani	3	307.2	Adds language for cutting notching and boring
<u>CC #</u> S196-22				
Approve As Submitted / Enhances the code. McStravick / Batts 9 Yes – 0 No				

Pending Review
TAC Action

AS AS/IC D

D/IC

Staff Classification
Correlates Directly

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11087	Mo Madani	3	307.2	Adds language for cutting notching and boring for wood framing
<u>CC #</u> S224-22				
Approve As Submitted / Enhances the code. McStravick / Batts 9 Yes – 0 No				

Pending Review
TAC Action

AS AS/IC D

D/IC

Staff Classification
Correlates Directly

4-Fixtures, Faucets and Fixture Fittings

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10851	Mo Madani	4	403.1	Adds language for "sleeping Units"
<u>CC #</u> G344-21 Part III				
Approve As Submitted / Enhances the Code Batts / McStravick 9 Yes – 0 No				

Pending Review
TAC Action

AS AS/IC D

D/IC

Staff Classification
Correlates Directly



Plumbing

TECHNICAL ADVISORY COMMITTEE

All Mods

Total Mods for this report: 101

TAC: Plumbing **101** Total Mods for **Plumbing** in **Pending Review**

Mod #	Proponent	Chapter	Section	Summary
10905	Mo Madani	4	403.1	Sets basic language for occupant load
CC # P21-21				
Approve As Submitted / Enhances the code. Gonzalez / Batts 9 Yes – 0 No				

Pending Review

TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification

Correlates Directly

Mod #	Proponent	Chapter	Section	Summary
10906	Mo Madani	4	403.1.1	Adds clarifying language regarding urinals
CC # P24-21 Part I				
This is a two part modification.				
Approve As Submitted / Clarifies the code. Gonzalez / Batts 9 Yes – 0 No				
Part 2 Approve As Submitted / Correlates Directly and clarifies the code. 9 Yes – 0 No				

Pending Review

TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification

Correlates Directly

Mod #	Proponent	Chapter	Section	Summary
10929	Mo Madani	4	403.3.6	Add exception for door locking
CC # P35-21				
Approve As Submitted / Enhances the code. Gonzalez / Bats 8 Yes – 1 No				

Pending Review

TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification

Correlates Directly



Plumbing

TECHNICAL ADVISORY COMMITTEE

All Mods

Total Mods for this report: 101

TAC: Plumbing **101** Total Mods for **Plumbing** in **Pending Review**

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10932	Mo Madani	4	407.2	Adds bathtub overflow clarification language
<u>CC #</u> P40-21	Approve As Submitted / clarifies the code Kozan / Duren 9 Yes – 0 No			

Pending Review
TAC Action

AS AS/IC D

D/IC

Staff Classification
Correlates Directly

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10933	Mo Madani	4	410.1	Updates drinking fountain standards
<u>CC #</u> P41-21	Approve As Submitted / clarifies the code Kozan / Nutter 9 Yes -0 No			

Pending Review
TAC Action

AS AS/IC D

D/IC

Staff Classification
Correlates Directly

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10934	Mo Madani	4	412.10	Changes standard to ASSE 1084
<u>CC #</u> P46-21	Approve As Submitted / Updates standards Kozan / Gonzalez 9 Yes -0 No			

Pending Review
TAC Action

AS AS/IC D

D/IC

Staff Classification
Correlates Directly



Plumbing

TECHNICAL ADVISORY COMMITTEE

All Mods

Total Mods for this report: 101

TAC: Plumbing **101** Total Mods for **Plumbing** in **Pending Review**

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10935	Mo Madani	4	412.2	Updates to ASSE 1014 Standard
<u>CC #</u> P47-21	Approve As Submitted / Correlates standard Kozan / Gonzalez 9 Yes -0 No			

Pending Review
TAC Action

AS AS/IC D

D/IC

Staff Classification
Correlates Directly

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10936	Mo Madani	4	419.6	Adds language regarding soap dispensers
<u>CC #</u> P49-21	Deny / doesn't belong in plumbing code and not part of plumbing scope of work Kozan / Duren 9 Yes – 0 No			

Pending Review
TAC Action

AS AS/IC D

D/IC

Staff Classification
Correlates Directly

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10937	Mo Madani	4	423.3	Updates reference standard to ASSE 1084 from 1082
<u>CC #</u> P50-21	Approve As Submitted / provides additional standards Kozan / Gonzalez 9 Yes – 0 No			

Pending Review
TAC Action

AS AS/IC D

D/IC

Staff Classification
Correlates Directly



Plumbing

TECHNICAL ADVISORY COMMITTEE

All Mods

Total Mods for this report: 101

TAC: Plumbing **101** Total Mods for **Plumbing** in **Pending Review**

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10938	Mo Madani	4	423.4	Updates water dispenser reference standards and language
<u>CC #</u> P51-21	Approve As Submitted / Updates Standards Kozan / Gonzalez 9 Yes – 0 No			

Pending Review
TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification
Correlates Directly

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10939	Mo Madani	4	424.2	requirements for urinals language in public restrooms
<u>CC #</u> P52-21	Approve As Submitted / Enhances the code. Duren / Kozan 9 Yes – 0 No			

Pending Review
TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification
Correlates Directly

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10996	Mo Madani	4	403.1	Table 403.1. This change corrects discrepancies inadvertently created by past code changes. This change resolves that by adding "or more than two dwelling units" to the description of R-1.
<u>CC #</u> G44-21 Part III	Approve As Submitted / Enhances the code. Kozan / Duren 9 Yes – 0 No			

Pending Review
TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification
Correlates Directly



Plumbing

TECHNICAL ADVISORY COMMITTEE

All Mods

Total Mods for this report: 101

TAC: Plumbing **101** Total Mods for **Plumbing** in **Pending Review**

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11640	Mo Madani	4	403.1.1	Clarifies language for Single-user toilet and bathing room fixtures
<u>CC #</u> P25-21	Motion to approve as submitted / clarifies the code Gonzalez / Nutter 9 Yes – 0 No			

Pending Review
TAC Action

AS AS/IC D

D/IC

Staff Classification
Correlates Directly

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11674	Mo Madani	4	403.2.1	Removes redundant language for clearer interpretation
<u>CC #</u> P32-21	Approve as Sumbitted / redundant Gonzalez / Nutter 9 Yes – 0 No			

Pending Review
TAC Action

AS AS/IC D

D/IC

Staff Classification
Correlates Directly

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11675	Mo Madani	4	403.4	This proposal seeks to bring IPC Section 403.4 (IBC Section 2902.4) into alignment with the changes made to IPC Sections 403.1.1 and 403.1.2
<u>CC #</u> P36-21	Approve As Submitted / Enhances the code. Gonzalez/ Batts 9 Yes – 0 No			

Pending Review
TAC Action

AS AS/IC D

D/IC

Staff Classification
Correlates Directly

5-Water Heaters



Plumbing

TECHNICAL ADVISORY COMMITTEE

All Mods

Total Mods for this report: 101

TAC: Plumbing **101** Total Mods for **Plumbing** in **Pending Review**

Mod #	Proponent	Chapter	Section	Summary
10941	Mo Madani	5	501.9	Sets requirement of lead content in water heaters
CC # P54-21				
Approve As Submitted / Enhances the code. Duren / Gonzalez 9 Yes – 0 No				

Pending Review

TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification
Correlates Directly

Mod #	Proponent	Chapter	Section	Summary
10947	Mo Madani	5	504.7	Adds more requirements for water heater pans to section
CC # P55-21				
Deny / needs more work – water heaters are not required to be elevated. Kozan / Batts 9 Ys- 0 No Kozan – also need to address the heat resistance of the plastic pan.				

Pending Review

TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification
Correlates Directly

Mod #	Proponent	Chapter	Section	Summary
11679	Mo Madani	5	501.9	Adds language for lead free requirements for water heaters
CC # P54-21 Part I				
Approve As Submitted / Enhances the code Duren/ Batts 9 Yes – 0 No				

Pending Review

TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification
Correlates Directly

6-Water Supply and Distribution



Plumbing

TECHNICAL ADVISORY COMMITTEE

All Mods

Total Mods for this report: 101

TAC: Plumbing **101** Total Mods for **Plumbing** in **Pending Review**

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10831	Mo Madani	6	609.1	Adds language for Ambulatory Care Facility
<u>CC #</u> G3-21 Part III	Approve As Submitted/ Enhances the code. Batts / Kozan 9 yes – 0 No			

Pending Review
TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification
Correlates Directly

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10949	Mo Madani	6	605.3	Adds new requirements to Table 605.3 for A554-16 Standard Specification for Welded Stainless Steel Mechanical Tubing
<u>CC #</u> P61-21 Part I	Approve As Submitted / Enhances the code. Duren /Batts 9 Yes – 0 No			

Pending Review
TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification
Correlates Directly

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10951	Mo Madani	6	605.4	Adds requirements for Standard Specification for Welded Stainless Steel Mechanical Tubing
<u>CC #</u> P62-21 Part I	Approve As Submitted / Enhances the code. Duren /Gonzalez 9 Yes – 0 No			

Pending Review
TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification
Correlates Directly



Plumbing

TECHNICAL ADVISORY COMMITTEE

All Mods

Total Mods for this report: 101

TAC: Plumbing **101** Total Mods for **Plumbing** in **Pending Review**

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10966	Mo Madani	6	605.5	Updates reference standard A554-16 Standard Specification for Welded Stainless Steel Mechanical Tubing
CC # P63-21 Part I				
Approve As Submitted / Enhances the code.-updates standards. Languille / Batts 9 Yes – 0 No				

Pending Review
TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification
Correlates Directly

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10972	Mo Madani	6	605.5	Adds updated ASTM F3347-20 reference standard requirements
CC # P64-21 Part I				
Approve As Submitted / Enhances the code. Languille / Gonzalez 9 Yes – 0 No				

Pending Review
TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification
Correlates Directly

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10974	Mo Madani	6	605.5	Updates referenced standard ASTM F3348-20b
CC # P65-21 Part I				
Approve As Submitted / Enhances the code. Languille / Gonzalez 9 Yes – 0 No				

Pending Review
TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification
Correlates Directly



Plumbing

TECHNICAL ADVISORY COMMITTEE

All Mods

Total Mods for this report: 101

TAC: Plumbing **101** Total Mods for **Plumbing** in **Pending Review**

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10976	Mo Madani	6	605.5	Change language to copper alloy for brass and bronze
<u>CC #</u> P67-21				
Approve As Submitted / Enhances the code. Languille / Gonzalez 9 Yes – 0 No				

Pending Review
TAC Action

AS AS/IC D

D/IC

Staff Classification
Correlates Directly

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10977	Mo Madani	6	605.7	Add stainless steel pipe line items to table
<u>CC #</u> P68-21 Part I				
Approve As Submitted / Enhances the code. Languille / Gonzalez 9 Yes – 0 No				

Pending Review
TAC Action

AS AS/IC D

D/IC

Staff Classification
Correlates Directly

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10979	Mo Madani	6	605.14.2	Add reference standards ASTM D2855-15 and F3328-18
<u>CC #</u> P74-21 Part I				
Approve As Submitted / Enhances the code. Mayfield / Gonzalez 9 Yes – 0 No				

Pending Review
TAC Action

AS AS/IC D

D/IC

Staff Classification
Correlates Directly



Plumbing

TECHNICAL ADVISORY COMMITTEE

All Mods

Total Mods for this report: 101

TAC: Plumbing **101** Total Mods for **Plumbing** in **Pending Review**

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10981	Mo Madani	6	605.14.2	Adds green cement type
<u>CC #</u> P75-21 Part I				
Approve as Submitted / enhances the code. Mayfield / Batts 9 Yes – 0 No				

Pending Review
TAC Action

AS AS/IC D
 D/IC

Staff Classification
Correlates Directly

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10982	Mo Madani	6	605.15.2	Adds reference standard ASTM and cement joint requirements
<u>CC #</u> P76-21 Part I				
Approve As Submitted / Enhances the code. Mayfield / Gonzalez 9 Yes – 0 No				

Pending Review
TAC Action

AS AS/IC D
 D/IC

Staff Classification
Correlates Directly

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10984	Mo Madani	6	606.1	Adds language for lower story buildings regarding full-open valves
<u>CC #</u> P85-21				
Approve As Submitted / Enhances the code. Mayfield /Batts 9 Yes – 0 No				

Pending Review
TAC Action

AS AS/IC D
 D/IC

Staff Classification
Correlates Directly



Plumbing

TECHNICAL ADVISORY COMMITTEE

All Mods

Total Mods for this report: 101

TAC: Plumbing **101** Total Mods for **Plumbing** in **Pending Review**

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10985	Mo Madani	6	607.2.1	Language regarding commercial energy provisions
<u>CC #</u> P89-21	Approve As Submitted / an effective pointer Kozan / Batts 8 Yes – 1 No			

Pending Review
TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification
Correlates Directly

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10986	Mo Madani	6	608.1	updates to the language and sizes of reference standards
<u>CC #</u> P92-21	Approve As Submitted / Updates standards Kozan / Batts 9 Yes – 0 No			

Pending Review
TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification
Correlates Directly

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10987	Mo Madani	6	608.17.1.2	Adds ASSE reference Standard requirements
<u>CC #</u> P99-21	Deny / Overlap Kozan /Duren 9 Yes – 0 No			

Pending Review
TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification
Overlap



Plumbing

TECHNICAL ADVISORY COMMITTEE

All Mods

Total Mods for this report: 101

TAC: Plumbing **101** Total Mods for **Plumbing** in **Pending Review**

Mod #	Proponent	Chapter	Section	Summary
10988	Mo Madani	6	608.17.1.2	Adds reference standard language for ASSE 1032
CC # P106-21	Deny / Overlap Batts / Duren 9 Yes – 0 No			

Pending Review
TAC Action

AS
 AS/IC
 D

D/IC

Staff Classification
Overlap

Mod #	Proponent	Chapter	Section	Summary
11681	Mo Madani	6	604.4	Adds footnote c to Table 604.4. Adds new standard USEPA 2018.
CC # P87-21 Part I	Approve As Submitted / consistency with national standards Kozan / Duren 9 Yes – 0 No			

Pending Review
TAC Action

AS
 AS/IC
 D

D/IC

Staff Classification
Correlates Directly

7-Sanitary Drainage

Mod #	Proponent	Chapter	Section	Summary
10989	Mo Madani	7	702.3	Add new reference standard ASTM F2763-16
CC # P107-21	Approve As Submitted / enhances the code Batts / McStravick 9 Yes – 0			

Pending Review
TAC Action

AS
 AS/IC
 D

D/IC

Staff Classification
Correlates Directly



Plumbing

TECHNICAL ADVISORY COMMITTEE

All Mods

Total Mods for this report: 101

TAC: Plumbing **101** Total Mods for **Plumbing** in **Pending Review**

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10990	Mo Madani	7	702.3	Adds reference standard ASTM F2947/F2947M-20
<u>CC #</u> P108-21	Approve As Submitted / enhances the code. Batts / McStravick 9 Yes – 0			

Pending Review
TAC Action

AS AS/IC D

D/IC

Staff Classification
Correlates Directly

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10991	Mo Madani	7	702.6	Adds drainage language to the section
<u>CC #</u> P111-21	Approve As Submitted / enhances the code. Batts / McStravick 9 Yes – 0			

Pending Review
TAC Action

AS AS/IC D

D/IC

Staff Classification
Correlates Directly

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11025	Mo Madani	7	702.1	Adds reference standard ASTM F3371-19 requirements
<u>CC #</u> P120-21 Part I	Approve As Submitted / enhances the code. Nutter / Gonzalez 9 Yes – 0			

Pending Review
TAC Action

AS AS/IC D

D/IC

Staff Classification
Correlates Directly



Plumbing

TECHNICAL ADVISORY COMMITTEE

All Mods

Total Mods for this report: 101

TAC: Plumbing **101** Total Mods for **Plumbing** in **Pending Review**

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11027	Mo Madani	7	705.16	Clarifies language on coupling types and removes confusing language
<u>CC #</u> P124-21	Approve As Submitted / enhances the code. Nutter / Gonzalez 9 Yes – 0			

Pending Review
TAC Action

AS AS/IC D

D/IC

Staff Classification
Correlates Directly

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11682	Mo Madani	7	705.10.2	Adds an exception 3 to Section 705.10.2 Solvent cementing. Adds new standard F3328-19.
<u>CC #</u> P117-21 Part I	Approve As Submitted / enhances the code., adds a needed expcetion. Nutter / Gonzalez 9 Yes – 0			

Pending Review
TAC Action

AS AS/IC D

D/IC

Staff Classification
Correlates Directly

11-Storm Drainage

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11028	Mo Madani	11	1102.7	Adds ASTM F2763-1 requirements
<u>CC #</u> P135-21	Approve As Submitted / enhances the code, .updates the standards Nutter / Gonzalez 9 Yes – 0			

Pending Review
TAC Action

AS AS/IC D

D/IC

Staff Classification
Correlates Directly



Plumbing

TECHNICAL ADVISORY COMMITTEE

All Mods

Total Mods for this report: 101

TAC: Plumbing **101** Total Mods for **Plumbing** in **Pending Review**

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11076	Mo Madani	11	1102.4	Adds reference standard requirements for CSA 182.8 i
<u>CC #</u> P136-21	Approve As Submitted / enhances the code. Nutter / Gonzalez 9 Yes – 0			

Pending Review
TAC Action

AS AS/IC D
 D/IC

Staff Classification
Correlates Directly

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11077	Mo Madani	11	1102.7	Adds reference standard requirements of ASTM F2764/2764M-19
<u>CC #</u> P138-21	Approve As Submitted / enhances the code. Nutter / Duren 9 Yes – 0			

Pending Review
TAC Action

AS AS/IC D
 D/IC

Staff Classification
Correlates Directly

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11078	Mo Madani	11	1102.7	Adds reference standard requirements for ASTM F2881/F2881M
<u>CC #</u> P139-21	Approve As Submitted / enhances and clarifies the code. Duren / Batts 9 Yes – 0			

Pending Review
TAC Action

AS AS/IC D
 D/IC

Staff Classification
Correlates Directly



Plumbing

TECHNICAL ADVISORY COMMITTEE

All Mods

Total Mods for this report: 101

TAC: Plumbing **101** Total Mods for **Plumbing** in **Pending Review**

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11079	Mo Madani	11	1102.5	Adds reference standard requirements of ASTM F405
CC # P140-21 Part I				

Approve As Submitted / enhances and clarifies the code. Duren / Gonzalez 9 Yes – 0

Pending Review
TAC Action

AS AS/IC D

D/IC

Staff Classification
Correlates Directly

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11081	Mo Madani	11	1102.4	Adds reference standard requirements for ASTM F2947/F2947M-20
CC # P142-21				

Approve As Submitted / enhances and clarifies the code. Duren / Gonzalez 9 Yes – 0

Pending Review
TAC Action

AS AS/IC D

D/IC

Staff Classification
Correlates Directly

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11082	Mo Madani	11	1102.7	Adds reference standard requirements of ASTM F667/F667M
CC # P143-21 Part I				

Approve As Submitted / updates the standards and enhances the code. Duren / Gonzalez 9 Yes – 0

Pending Review
TAC Action

AS AS/IC D

D/IC

Staff Classification
Correlates Directly



Plumbing

TECHNICAL ADVISORY COMMITTEE

All Mods

Total Mods for this report: 101

TAC: Plumbing **101** Total Mods for **Plumbing** in **Pending Review**

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11084	Mo Madani	11	1102.7	Adds reference standard requirements for ASTM F3202-19a
CC # P144-21				
Approve As Submitted / updates the standards and enhances the code. Duren /Gonzalez 9 Yes – 0				

Pending Review TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification
Correlates Directly

13-Non Potable Water Systems

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10830	Mo Madani	13	1302.9	Changes language from "easily accessible" to easy access
CC # G1-21 Part IV				
Deny / Overlap Schilling / Batts 9 Yes – 0 No				

Pending Review TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification
Overlap

SubCode: Residential

25-Plumbing Administration

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11622	Mo Madani	25	2503.5.2	Deletes and substitutes P2503.5.2 "Drainage and vent final test".
CC # RP1-21				
Approve As Submitted / eliminates obsolete practices.. Kozan / Gonzalez 9 Yes – 0				

Pending Review TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification
Correlates Directly

26-General Plumbing Requirements



Plumbing

TECHNICAL ADVISORY COMMITTEE

All Mods

Total Mods for this report: 101

TAC: Plumbing **101** Total Mods for **Plumbing** in **Pending Review**

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10887	Mo Madani	26	2603.2.1	Adds language for P2603.2.1.1 Shield plates
Deny / companion to a previous mod disapproved. Consistent with action on Mod 10866 - Kozan / Duren 9 Yes – 0 No				

Mod #
10887

CC #
P6-21 Part II

Pending Review

TAC Action

AS AS/IC D

D/IC

Staff Classification
Correlates Directly

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11352	Mo Madani	26	2603	Adds new section P2603.2.1.1 "Shield plates". Modifies text of M1308.2.1, M1308.2.2/
Deny / companion to a previous mod disapproved. Consistent with action on Mod 10866 - Kozan / Schilling 9 Yes – 0 No				

Mod #
11352

CC #
P6-21 Part II

Pending Review

TAC Action

AS AS/IC D

D/IC

Staff Classification
Correlates Directly

27-Plumbing Fixtures

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11623	Mo Madani	27	2704.1	The 2015-2017 PMGCAC successfully changed IRC Section P2704.1 concerning the location of slip joints. However, an error was made at the PMGCAC level that was not noticed by anyone until the 2018 IRC was published.
Approve As Submitted / clarifies the code Kozan McStravick 9 Yes – 0 No				

Mod #
11623

CC #
RP3-21

Pending Review

TAC Action

AS AS/IC D

D/IC

Staff Classification
Correlates Directly



Plumbing

TECHNICAL ADVISORY COMMITTEE

All Mods

Total Mods for this report: 101

TAC: Plumbing **101** Total Mods for **Plumbing** in **Pending Review**

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11624	Mo Madani	27	2709.3	A simple pointer to help the user locate the necessary information that goes hand in hand with the requirements for building a shower receptor.
<u>CC #</u> RP4-21				

Approve As Submitted / clarifies the code and provides a needed pointer. Kozan / Duren 9 Yes – 0 No

Pending Review
TAC Action

AS AS/IC D
 D/IC

Staff Classification
Correlates Directly

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11625	Mo Madani	27	2717.2	An editorial cleanup of Section P2717.2.
<u>CC #</u> RP5-21				

Approve As Submitted / enhances the code McStravick / Batts 9 Yes – 0 No

Pending Review
TAC Action

AS AS/IC D
 D/IC

Staff Classification
Correlates Directly

28-Water Heaters

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10945	Mo Madani	28	2801.9	Residential Code language for lead volume in water heaters
<u>CC #</u> P54-21 Part II				

Approve As Submitted / improves the code Duren / Kozan 9 Yes – 0 No

Pending Review
TAC Action

AS AS/IC D
 D/IC

Staff Classification
Correlates Directly



Plumbing

TECHNICAL ADVISORY COMMITTEE

All Mods

Total Mods for this report: 101

TAC: Plumbing **101** Total Mods for **Plumbing** in **Pending Review**

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11626	Mo Madani	28	2801.1	Deletes Section P2801.1 "Required".
<u>CC #</u> RP6-21				
Approve As Submitted / proponents justification and Enhances the code McStravick / Batts 9 Yes – 0 No				

Pending Review

TAC Action

AS AS/IC D

D/IC

Staff Classification

Correlates Directly

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11627	Mo Madani	28	2801.6.3	Adds new Section P2801.6.3 "Appliance, equipment and insulation in pans".
<u>CC #</u> RP7-21				
Deny / consistency with previous action McStravick/ Batts 9 Yes – 0 No				

Pending Review

TAC Action

AS AS/IC D

D/IC

Staff Classification

Correlates Directly

29-Water Supply and Distribution

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10965	Mo Madani	29	2906.5	Adds A554-16 Standard Specification for Welded Stainless Steel Mechanical Tubing language to Residential
<u>CC #</u> P62-21 Part II				
Approve As Submitted /Enhances the code Languille / Gonzalez 9 Yes – 0 No				

Pending Review

TAC Action

AS AS/IC D

D/IC

Staff Classification

Correlates Directly



Plumbing

TECHNICAL ADVISORY COMMITTEE

All Mods

Total Mods for this report: 101

TAC: Plumbing **101** Total Mods for **Plumbing** in **Pending Review**

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10971	Mo Madani	29	2906.6	Adds ASTM reference standard A554-16 Standard Specification for Welded Stainless Steel Mechanical Tubing to Residential Code
<u>CC #</u> P63-21 Part II				
Approve As Submitted / Enhances the code Languille / Gonzalez 9 Yes – 0 No				

Pending Review
TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification
Correlates Directly

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10975	Mo Madani	29	2096.6	Adds reference standard ASTM F3348-20b to the Residential
<u>CC #</u> P65-21 Part II				
Approve As Submitted / Enhances the code Languille / Batts 9 Yes – 0 No				

Pending Review
TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification
Correlates Directly

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10978	Mo Madani	29	2903.9.4	Add referenced standard for stainless steel ball valves
<u>CC #</u> P68-21 Part II				
Approve As Submitted / Enhances the code Mayfield / Duren 9 Yes – 0 No				

Pending Review
TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification
Correlates Directly



Plumbing
TECHNICAL ADVISORY COMMITTEE

All Mods

Total Mods for this report: 101

TAC: Plumbing **101** Total Mods for **Plumbing** in **Pending Review**

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10980	Mo Madani	29	2906.9.1.2	Add reference standards and language regarding cement joints

CC #
P74-21 Part II

Pending Review
TAC Action

AS AS/IC D

D/IC

Staff Classification

Correlates Directly

Approve As Submitted / Enhances the code Mayfield / McStravick 9 Yes – 0 No

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
10983	Mo Madani	29	2906.9.1.3	Adds ASTM reference standard for cement joints to Residential

CC #
P76-21 Part II

Pending Review
TAC Action

AS AS/IC D

D/IC

Staff Classification

Correlates Directly

Approve As Submitted / Enhances the code update the standards. Mayfield / Gonzalez 9 Yes – 0 No

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11343	Mo Madani	29	2904.1	Proposal correlates several of the I codes to use the defined term of automatic sprinkler system.

CC #
F75-21 Part II

Pending Review
TAC Action

AS AS/IC D

D/IC

Staff Classification

Overlap

Deny / Overlap Schilling / Duren 9 Yes – 0 No



Plumbing
TECHNICAL ADVISORY COMMITTEE

All Mods

Total Mods for this report: 101

TAC: Plumbing **101** Total Mods for Plumbing in Pending Review

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11350	Mo Madani	29	2906.6	Adds new reference standard ASTM F3347 "Standard Specification for Metal Press Insert Fittings with Factory Assembled Stainless Steel Press Sleeve for SDR9 Cross-linked Polyethylene (PEX) Tubing and SDR9 Polyethylene of Raised Temperature (PE-RT) Tubing
<u>CC #</u> M99-21 Part II				

Pending Review
TAC Action

AS AS/IC D

D/IC

Staff Classification

Correlates Directly

Approve As Submitted / Enhances the code McStravick / Batts 9 Yes – 0 No

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11356	Mo Madani	29	2906.6	Table P2906.6. ASTM F3347 is titled, "Standard Specification for Metal Press Insert Fittings with Factory Assembled Stainless Steel Press Sleeve for SDR9 Cross-linked Polyethylene (PEX) Tubing and SDR9 Polyethylene of Raised Temperature (PE-RT) Tubing.
<u>CC #</u> P64-21 Part II				

Pending Review
TAC Action

AS AS/IC D

D/IC

Staff Classification

Correlates Directly

Approve As Submitted / Enhances the code Languille / Gonzalez 9 Yes – 0 No

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11360	Mo Madani	29	2906.9.1.2	Currently, it can be difficult to see the yellow solvent cement ring on a tan CTS CPVC joint during inspection.
<u>CC #</u> P75-21 Part II				

Pending Review
TAC Action

AS AS/IC D

D/IC

Staff Classification

Correlates Directly

Approve As Submitted / Enhances the code Mayfield / Batts 9 Yes – 0 No



Plumbing

TECHNICAL ADVISORY COMMITTEE

All Mods

Total Mods for this report: 101

TAC: Plumbing **101** Total Mods for **Plumbing** in **Pending Review**

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11628	Mo Madani	29	2903.6	Adds new Section P2903.6 "Existing piping used for grounding".
<u>CC #</u> RP8-21				
Approve As Submitted / Enhances the code McStravick / Batts 8 Yes – 1 No				

Pending Review
TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification
Correlates Directly

30-Sanitary Drainage				
<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11024	Mo Madani	30	3003.9.2	Adds requirements for reference standard ASTM F3328
<u>CC #</u> P117-21 Part II				
Approve As Submitted / Enhances the code Nutter / Gonzalez 9 Yes – 0 No				

Pending Review
TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification
Correlates Directly

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11026	Mo Madani	30	3002.1	Adds ASTM F3371-19 reference standard requirements
<u>CC #</u> P120-21 Part II				
Approve As Submitted / Enhances the code Nutter / Gonzalez 9 Yes – 0 No				

Pending Review
TAC Action

AS
 AS/IC
 D
 D/IC

Staff Classification
Correlates Directly



Plumbing

TECHNICAL ADVISORY COMMITTEE

All Mods

Total Mods for this report: 101

TAC: Plumbing **101** Total Mods for **Plumbing** in **Pending Review**

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11080	Mo Madani	30	3009.11	Adds reference standard requirements of ASTM F405
CC # P140-221 Part II				
Deny / Overlap Duren / Gonzalez 9 Yes – 0 No				

Pending Review TAC Action

AS AS/IC D

D/IC

Staff Classification
Overlap

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11364	Mo Madani	30	3009	Adds new standard Table 3009.11, Table P3302.1.
CC # P140-21 Part II				
Deny / Overlap Duren / Gonzalez 9 Yes – 0 No				

Pending Review TAC Action

AS AS/IC D

D/IC

Staff Classification
Overlap

31-Vents

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11629	Mo Madani	31	3101.5	This proposal is editorial in nature. This proposal is to correct references to section numbers for flood resistance requirements.
CC # RP11-21				
Approve As Submitted / Editorial Kozan / Gonzalez 9 Yes – 0 No				

Pending Review TAC Action

AS AS/IC D

D/IC

Staff Classification
Correlates Directly

33-Storm Drainage



Plumbing

TECHNICAL ADVISORY COMMITTEE

All Mods

Total Mods for this report: 101

TAC: Plumbing **101** Total Mods for **Plumbing** in **Pending Review**

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
11365	Mo Madani	33	3302	The proposal to add this standard to Table 1102.7 - Pipe Fittings is just to highlight that the pipe standard listed on Table 1102.4 and 1102.5 covers fittings as well as pipe.
<u>CC #</u> P143-21 Part II				
Deny / Overlap Duren / Gonzalez 9 Yes – 0 No				

Pending Review

TAC Action

AS
 AS/IC
 D

D/IC

Staff Classification

Overlap

<u>Mod #</u>	<u>Proponent</u>	<u>Chapter</u>	<u>Section</u>	<u>Summary</u>
3317-11085	Mo Madani	3317	101	Adds new appendix language regarding non-sewered sanitation systems
<u>CC #</u> P147-21 Part II				
Deny / does not belong in residential code / Gonzalez / Batts 9 Yes – 0 No				

Pending Review

TAC Action

AS
 AS/IC
 D

D/IC

Staff Classification

Correlates Directly

Search Criteria

Modification #: ALL
Code Change Cycle: 2026 ICC Code Change Original Modification
Chapter & Topic: ALL
Date Submitted From: ALL
TAC: P
Commission Action: ALL
Proponent Last Name: ALL
Text of Modification: ALL
Affects HVHZ: ALL

Code Version: 2026
Sub Code: ALL
Section: ALL
Date Submitted To: ALL
TAC Recommendation: ALL
Modification Status: Verified
Proponent First Name: ALL
Related Modifications: ALL
Archived: No