

# AAMA CERTIFICATION PROGRAM



## AUTHORIZATION FOR PRODUCT CERTIFICATION

**Simonton Windows**  
**1 Cochrane Ave.**  
**Pennsboro, WV 26415**

**Attn: Tina Jenkins**

The product described below is hereby approved for listing in the next issue of the AAMA Certified Products Directory. The approval is based on successful completion of tests, and the reporting to the Administrator of the results of tests, accompanied by related drawings, by an AAMA Accredited Laboratory.

1. The listing below will be added to the next published AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED			
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08 R-PG50-1854x1575 (73x62)-HS</b>	<b>AAMA 506</b>				
COMPANY AND PLANT LOCATION	Missile Level: <b>D</b> Rating: <b>+50/-50, 73x62</b> Wind Zone: <b>4</b> Rating above conforms to requirements of: <b>ASTM E1886 and E1996</b>	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
<b>Simonton Windows Code: SIM</b>		<b>11478</b>	<b>07-09 HORIZONTAL SLIDER (PVC) (OX) (OG) (INS LAM GL) (REINF) (MODIF) (ASTM)</b>	<b><u>FRAME(mm)</u> 1854 x 1575 (6'1" x 5'2")</b>	<b><u>SASH(mm)</u> 911 x 1467 (3'0" x 4'10")</b>

2. This Certification will expire **August 27, 2017** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

3. Structural Test & Report By:

**Architectural Testing, Inc.**

Report No: **D0968.01-501-47**

Date of Report: **September 16, 2013**

Missile Impact Test & Report by:

**Architectural Testing, Inc.**

Report No: **D0967.01-501-47**

Date of Report: **September 19, 2013**

Validated for Certification

Associated Laboratories, Inc.

Authorized for Certification

American Architectural Manufacturers Association

Date: **September 28, 2013**

Cc: AAMA  
SBS