

AAMA CERTIFICATION PROGRAM



AUTHORIZATION FOR PRODUCT CERTIFICATION

Simonton Windows
1 Cochrane Ave.
Pennsboro, WV 26415

Attn: Tina Jenkins Seese

The product described below is hereby approved for listing in the next issue of the AAMA Certified Products Directory. The approval is based on successful completion of tests, and the reporting to the Administrator of the results of tests, accompanied by related drawings, by an AAMA Accredited Laboratory.

1. The listing below will be added to the next published AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-08 R-PG50-1854x1575 (73x62)-HS	AAMA 506				
COMPANY AND PLANT LOCATION	Missile Level: D Rating: +50/-50, 73x62 Wind Zone: 4 Rating above conforms to requirements of: ASTM E1886 and E1996	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
Simonton Windows Code: SIM		12835	07-20STORMBREAKER HORIZONTAL SLIDER (PVC) (OX) (OG) (INS PVB LAM GL) (REINF) (MODIF) (ASTM)	<u>FRAME(mm)</u> 1854 x 1575 (6'1" x 5'2")	<u>SASH(mm)</u> 911 x 1467 (3'0" x 4'10")

2. This Certification will expire **August 27, 2017** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

3. Structural Test & Report By:

Architectural Testing, Inc.

Report No: **D0968.01-501-47**

Date of Report: **September 16, 2013**

Missile Impact Test & Report by:

Architectural Testing, Inc.

Report No: **D8020.01-109-47; Ref. D0967.01-501-47**

Date of Report: **June 9, 2014; September 19, 2013**

Validated for Certification

Associated Laboratories, Inc.

Authorized for Certification

American Architectural Manufacturers Association

Date: **July 8, 2014**
 Revised: **March 3, 2016**
 Cc: AAMA
 SBS