



AUTHORIZATION FOR PRODUCT CERTIFICATION

**Simonton Windows
1 Cochrane Dr.
Pennsboro, WV 26415**

Attn: Tina Seese

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-08 R-PG50-2870x1600 (113x63)-HS	AAMA 506-06				
COMPANY AND CODE	Missile Level: D Rating: +50/-50, 113x63 Wind Zone: 4	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
Simonton Windows Code: SIM	Rating above conforms to the requirements of: ASTM E1886 and E1996	16040	07-09/07-20 HS (PVC)(XOX)(OG) (PVB LAM GL)(MODIF) (REINF)(ASTM)	FRAME (mm) 2870 x 1600 (9'5" x 5'3")	SASH (mm) 941 x 1492 (3'1" x 4'11")

This Certification will expire **October 10, 2021** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Structural Test & Report By:

PRI Construction Materials Technologies, LLC

Report No: **SIMO-028-03-02**

Date of Report: **October 27, 2016**

Missile Impact Test & Report By:

PRI Construction Materials Technologies, LLC

Report No: **SIMO-028-03-01**

Date of Report: **October 27, 2016**

Evaluated for Certification: **November 2, 2016**

Associated Laboratories, Inc.

Authorized for Certification: **November 2, 2016**

American Architectural Manufacturers Association