

**AAMA
CERTIFICATION PROGRAM**



AUTHORIZATION FOR PRODUCT CERTIFICATION

**Simonton Windows
1 Cochrane Ave.
Pennsboro, WV 26415**

Attn: Tina Seese

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of tests by an AAMA Accredited Laboratory. The listing below will be added to the next update to the AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-08 R-PG50*-2870x1600 (113x63)-HS	AAMA 506				
COMPANY	Missile Level: D Rating: +50/-50, 113x63 Wind Zone: 4 Rating above conforms to requirements of: ASTM E1886 and E1996	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
Simonton Windows Code: SIM		16175	07-09/07-20 HORIZONTAL SLIDER (PVC) (XOX) (OG) (INS TEMP/ PVB LAM GL) (MODIF) (REINF) (ASTM)	<u>FRAME(mm)</u> 2870 x 1600 (9'5" x 5'3")	<u>SASH(mm)</u> 600 x 1391 (2'0" x 4'7")

1. This Certification will expire **October 12, 2021** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

3. Structural Test & Report By:

PRI Construction Materials Technologies

Report No: **SIMO-028-03-04**

Date of Report: **October 27, 2016**

Missile Impact Test & Report by:

PRI Construction Materials Technologies

Report No: **SIMO-032-03-01**

Date of Report: **December 21, 2016**

Evaluated for Certification: **January 4, 2017**

Associated Laboratories, Inc.

Authorized for Certification: **January 4, 2017**

American Architectural Manufacturers Association

SBS/JTS