



AUTHORIZATION FOR PRODUCT CERTIFICATION

**Simonton Windows
1 Cochrane Dr.
Pennsboro, WV 26415**

Attn: Tina Seese

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-08 R-PG50-1854x1575 (73x62)-HS	AAMA 506				
COMPANY AND CODE	Missile Level: D Rating: +50/-50, 73x62 Wind Zone: 4	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
Simonton Windows Code: SIM	Rating above conforms to the requirements of: ASTM E1886 and E1996	11478 & 12835	07-09/07-20 STORMBREAKER PLUS HS (PVC)(OX)(OG) (INS PVB LAM GL) (MODIF)(REINF)(ASTM)	<u>FRAME (mm)</u> 1854 x 1575 (6'1" x 5'2")	<u>SASH (mm)</u> 911 x 1467 (3'0" x 4'10")

This Certification will expire **August 27, 2022 (extended from August 27, 2017 per AAMA 103-15)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Structural Test & Report By:

Architectural Testing, Inc.

Report No: **D0968.01-501-47**

Date of Report: **September 16, 2013**

Missile Impact Test & Report By:

Architectural Testing, Inc.

Report No: **D8020.01-109-47; ref. D0967.01-501-47**

Date of Report: **June 9, 2014; September 19, 2013**

Evaluated for Certification: **February 14, 2017**

Associated Laboratories, Inc.

Authorized for Certification: **February 14, 2017**

American Architectural Manufacturers Association