

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011355-R4  
DATE: 12/14/2012  
CERTIFICATION PROGRAM: Structural  
COMPANY: Nan Ya  
CODE: 661-1  
REVISION DATE: 08/10/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Nan Ya Plastics Corporation USA</b> <b>8989 North Loop East, Suite 800</b> <b>Houston, TX 77029</b>	<b>Series "SRS" Gliding Patio Door</b> <b>w/Field Mullion</b> Configuration: OX/O Glazing: IG-1/8" Tempered Glass/1/8" Annealed Glass  Frame: W-3693mm(145.38") H-2092mm(82.38") Panel: W-1213mm(47.75") H-2013mm(79.25") DLO: W-940mm(37") H-1676mm(66")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class R-PG50 3693 X 2092 (146 x 83)-SD</b> <b>Design Pressure: 2400 Pa (50 psf)</b> Qualifies Configurations: O/X/OX/XO/OX/O/O/XO

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-210-3821-1  
Expiration Date: **June 30, 2032**

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)