

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011356.02-R3  
**DATE:** 12/14/2012  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Nan Ya  
**CODE:** 661-1  
**REVISION DATE:** 08/10/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Nan Ya Plastics Corporation USA</b> <b>8989 North Loop East, Suite 800</b> <b>Houston, TX 77029</b>	<b>Series "SPLS"</b> <b>Gliding Patio Door</b> Configuration: OXXO  Glazing: IG-1/8" Tempered Glass/Laminate-1/8" Annealed Glass/0.090" PVB Interlayer/1/8" Annealed Glass  Frame: W-3585mm(141.13") H-2093mm(82.38") Panel: W-908mm(35.75") H-2013mm(79.25") DLO: W-667mm(26.75") H-1676mm(66")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>ASTM E1886-02/04/05/E1996-04/06/09</b>	<b>Class R-PG50 3585 X 2093 (142 x 83)-SD</b> <b>Design Pressure: +50/-50 psf</b> <b>Wind Zone 4 - Missile Level D</b> Qualifies Configurations: O/X/OX/XO/OXO/XXO/OXX/OXXO

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-210-3821-5  
Expiration Date: **June 30, 2032**

Administrator's Signature:  \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)