

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011609-R1
DATE: 07/16/2013
CERTIFICATION PROGRAM: Structural
COMPANY: Nan Ya Plastics
CODE: 661-1
REVISION DATE: 03/16/2017

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Nan Ya Plastics Corporation U.S.A. 8989 North Loop East Houston, TX 77029	"MasterPiece Series Gliding Patio Door" Vinyl Sliding Glass Door Configuration: XO Glazing: Insulating Glass (Tempered) Frame: W-1810mm(71.25") H-2019mm(79.5") Panel: W-908mm(35.75") H-1946mm(76.63") DLO: W-667mm(26.25") H-1676mm(66")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG45 1810 x 2019 (71 x 80)-SD Design Pressure: 2160 Pa (45 psf) Water Penetration Resistance Test Pressure: 324 Pa(6.75 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3878-01
Expiration Date: **April 30, 2025**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122