

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011932-R2
DATE: 04/14/2014
CERTIFICATION PROGRAM: Structural
COMPANY: Nan Ya Plastics
CODE: 661-1
REVISION DATE: 08/01/2018

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Nan Ya Plastics Corporation U.S.A. 8989 North Loop East Houston, TX 77029	Series "Gliding 3-Panel Patio Door" Sliding Door w/Field Mullion Configuration: O/XO Glazing: Insulating Glass (Tempered) Frame: W-2804mm(110.38") H-2096mm(82.5") Panel: W-908mm(35.75") H-2022mm(79.59") DLO: W-667mm(26.25") H-1676mm(66")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG50 2804 x 2096 (110 x 83)-SD Design Pressure: 2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 360 Pa(7.5 psf) Qualified Configurations: O/X, O/O, O/XO, O/OX

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3932-01
Expiration Date: March 31, 2026

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122