NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013729.08-R1

DATE: 06/02/2017

CERTIFICATION PROGRAM: Structural

COMPANY: Nan Ya

CODE: 661-1

REVISION DATE: <u>09/21/2020</u>

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status.

Please review and advise NAMI if any corrections are required to this document.

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---------------------------------|--|
| Nan Ya Plastics Corporation USA | Series "LPS Gliding Patio Door" Glazed |
| 8989 North Loop East, Suite 800 | Fiberglass Sliding Glass Door |
| Houston, TX 77029 | w/Sill Riser & Bubble Cover |
| | Configuration: XXO Glazing: IG-1/8" Tempered Glass/1/8" Annealed Glass/0.090" Kuraray PVB Interlayer//1/8" Annealed Glass |
| | Frame: W-2692mm(106") H-2426mm(95.5") |
| | Panel: W-908mm(35.75") H-2352mm(92.59") |
| | DLO: W-635mm(25") H-2007mm(79") |

| SPECIFICATION | PRODUCT RATING |
|---|--|
| AAMA/WDMA/CSA 101/I.S.2/A440-11 ASTM E1886-05 ASTM E1996-05/09 CSA A440S1-09 | Class R-PG50 2692 x 2426 (106 x 95)-SD Design Pressure: ±2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 720 Pa (15.0 psf) Canadian Air Infiltration/Exfiltration Level: A2 Wind Zone 4 - Missile Level D Qualifies Configurations: O/X/OX/XO/OXX/XXO/XX |

Product Tested By: National Certified Testing Laboratories

Report No: NCTL-210-4058-02 Expiration Date: **February 28, 2025**

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

Fax: (804) 684-5122