

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014136-R1
DATE: 06/15/2018
CERTIFICATION PROGRAM: Structural
COMPANY: Nan Ya
CODE: 661-1
REVISION DATE: 09/15/2020

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Nan Ya Plastics Corporation USA 8989 North Loop East, Suite 800 Houston, TX 77029	Series "SPLS" Fiberglass Glazed Sliding Glass Door Assembly Configuration: OXXO Glazing: IG- 1/8" Tempered Glass/1/8" Tempered Glass/0.090" Kuraray Trosifol PVB Interlayer/1/8" Tempered Glass Frame: W-3585mm(141.13") H-2426mm(95.5") Panel: W-908mm(35.75") H-2346mm(92.38") DLO: W-635mm(25") H-2007mm(79")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 CSA A440S1-09 ASTM E1886-05 ASTM E1996-05/09	Class R-PG50 3585 x 2426 (141 x 96)-SD Design Pressure: ±2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.5 psf) Canadian Air Infiltration/Exfiltration Level: A2 Wind Zone 4 - Missile Level D

Product Tested By: National Certified Testing Laboratories

Report No: NCTL-210-4103-01A

Expiration Date: **December 31, 2025**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122