

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI009467-R3
DATE: 05/19/2007
CERTIFICATION PROGRAM: Structural
COMPANY: Nan Ya
CODE: 661-1
REVISION DATE: 07/29/2014

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Nan Ya Plastics Corporation USA 8989 North Loop East, Suite 800 Houston, TX 77029	"Fiberglass Gliding French Patio Doors" w/Reinforced Sidelites Fiberglass Sliding Glass Door Configuration: OXXO Glazing: IG-1/8" Tempered Glass/ Laminate-1/8" Annealed Glass/0.090" PVB by Solutia/ 1/8" Annealed Glass Frame: W-3585mm(141.13") H-2426mm(95.5") Panel: W-908mm(35.75") H-2346mm(92.38")

SPECIFICATION	PRODUCT RATING
ANSI/AAMA/NWDA 101/I.S.2-97 TAS 201/202/203-94 ASTM E1886-02/E1996-02 ASTM E1304-02	SGD-R50 Design Pressure: ±2400 Pa (50 psf) Large Missile Impact Rated Wind Zone 4-Missile Level D FER-Passed

Product Tested By: Certified Testing Laboratories
Report No: CTLA-1602W/CTLA-1602W-1/CTLA-1602W-2
Expiration Date: **February 28, 2015**

Administrator's Signature: _____ 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124 Fax: (804) 684-5122