

Hallmark® Certificate of Conformance and License (CCL)




Marvin
PO Box 100
401 State Ave N.
Warroad, MN 56763

Mfr ID: 407
For more Information visit www.amscert.com
Website: www.marvin.com
TEL: 218-386-1430

<i>Product No.</i>	<i>Product Name</i>	<i>Standard</i>	<i>Rating</i>	<i>Wide</i>	<i>High</i>	<i>Test Report #</i>	<i>CertDate</i>	<i>ExpDate</i>
407-H-1159.00	Infinity Outswing Bifold Door and Elevate Outswing Bifold Door	101/I.S.2/A440-17	Class LC-PG30; Size Tested 3850 x 2426 Type-FLD; DP +30/-30 psf; Water Test Press 220Pa (4.59psf)	3850	2426	M0055.01-201-47	3/5/2021	2/16/2031
407-H-1159.01	Infinity Outswing Bifold Door and Elevate Outswing Bifold Door	101/I.S.2/A440-17	Class LC-PG30; Size Tested 3850 x 2426 Type-FLD; DP +30/-30 psf; Water Test Press 220Pa (4.59psf)	3850	2426	M3190.01-201-47-R2	6/16/2021	4/29/2031
407-H-1159.02	Infinity Outswing Bifold Door and Elevate Outswing Bifold Door	101/I.S.2/A440-17	Class LC-PG30; Size Tested 998 x 2426 Type-FD; DP +30/-30 psf; Water Test Press 220Pa (4.59psf)	998	2426	M3190.01-201-47-R2	6/16/2021	4/29/2031
407-H-1159.03	Infinity Outswing Bifold Door and Elevate Outswing Bifold Door	101/I.S.2/A440-17	Class LC-PG30; Size Tested 998 x 2426 Type-FLD; DP +30/-30 psf; Water Test Press 220Pa (4.59psf)	998	2426	M3190.01-201-47-R1	11/14/2022	4/29/2031
407-H-1159.04	Infinity Outswing Bifold Door and Elevate Outswing Bifold Door	101/I.S.2/A440-17	Class LC-PG30; Size Tested 3854 x 2426 Type-FLD; DP +30/-30 psf; Water Test Press 220Pa (4.59psf)	3854	2426	M3190.01-201-47-R1	11/14/2022	4/29/2031

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  **John McFee, VP of Certification Programs, WDMA Hallmark**

By:  **Lucas L. Wenzel, Authorized Representative, AMS**

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com