

# Hallmark® Certificate of Conformance and License (CCL)




Marvin  
PO Box 100  
401 State Ave N.  
401 State Ave N.  
Warroad, MN 56763

*Mfr ID:* 407  
*For more Information visit* [www.amscert.com](http://www.amscert.com)  
*Website:* [www.marvin.com](http://www.marvin.com)  
*TEL:* 218-386-1430

<i>Product No.</i>	<i>Product Name</i>	<i>Standard</i>	<i>Rating</i>	<i>Wide</i>	<i>High</i>	<i>Test Report #</i>	<i>CertDate</i>	<i>ExpDate</i>
407-H-992.32	Ultimate Awning Narrow Frame Push Out 7236 & Ultimate Awning Push Out 7236	101/I.S.2/A440-11	Class LC-PG50; Size Tested 1829mm x 892mm (72"x35-1/8") Type-AP; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	1829mm	892mm	J7040.01-201-47-r2	8/21/2019	5/1/2029
407-H-992.33	Ultimate Awning Narrow Frame Push Out 7236 & Ultimate Awning Push Out 7236	101/I.S.2/A440-17	Class LC-PG50; Size Tested 1829mm x 892mm (72"x35-1/8") Type-AP; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	1829mm	892mm	J7040.01-201-47-r2	8/21/2019	5/1/2029

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

*By:*  John McFee, VP of Certification Programs, WDMA Hallmark

*By:*  Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor:  
Window and Door Manufacturers Assoc  
330 N. Wabash Avenue, Suite 2000  
Chicago, IL 60611  
TEL (312)673-4828 [www.wdma.com](http://www.wdma.com)

Program Administrator:  
Administrative Management Systems, Inc.  
PO Box 730, 205 West Main  
Sackets Harbor, NY 13685  
TEL (315)646-2234 [staff@amscert.com](mailto:staff@amscert.com)