

Hallmark® Certificate of Conformance and License (CCL)



Kolbe & Kolbe Millwork Co.
1323 South 11th Avenue
Wausau, WI 54401

Mfr ID: 413


For more Information visit www.amscert.com

Website: www.kolbewindows.com

TEL:

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
413-H-1278.06	Heritage Traditional Double Hung (SP) Combination Mulled Along Side A Heritage Traditional Double Hung Studio (SP) (R&D #12071)	101/I.S.2/A440-11	Class LC-PG25; Size Tested 1156mm x 2043mm Type-H; DP +25/-25 psf; Water Test Press 180Pa (3.76psf); Can. Air Infil/Exfil. Level=A3	1156mm	2043mm	ESP012890P-1402	4/10/2018	10/8/2023
413-H-1278.07	Heritage Traditional Double Hung (SP) Combination Mulled Along Side A Heritage Traditional Double Hung Studio (SP) (R&D #12071)	101/I.S.2/A440-11	Class LC-PG25; Size Tested 1968mm x 2043mm Type-FW; DP +25/-25 psf; Water Test Press 180Pa (3.76psf); Can. Air Infil/Exfil. Level=A3	1968mm	2043mm	ESP012890P-1402	4/10/2018	10/8/2023
413-H-1278.08	Heritage Traditional Double Hung (SP) Combination Mulled Along Side A Heritage Traditional Double Hung Studio (SP) (R&D #12071)	101/I.S.2/A440-11	Class LC-PG25; Size Tested 2043mm span/1562mm trib width (80.44 in. span/61.5 in. trib width) Type-MA; DP +25/-25 psf; Water Test Press 180Pa (3.76psf); Can. Air Infil/Exfil. Level=A3	1562mm trib wisth	2043mm span	ESP012890P-1402	4/10/2018	10/8/2023

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  John McFee, VP of Certification Programs, WDMA Hallmark

By:  Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com