

Hallmark® Certificate of Conformance and License (CCL)



Kolbe & Kolbe Millwork Co.
1323 South 11th Avenue
Wausau, WI 54401

Mfr ID: 413


For more Information visit www.amscert.com

Website: www.kolbewindows.com

TEL:

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
413-H-1222.16	Ultra Outswing Entrance Door onelite, w/raised panels, opaque, EE, HP (R&D 11160)	101/I.S.2/A440-11	Class LC-PG65; Size Tested 2504mm span/960mm tributary width (98.5 in. span/37.78 in. tributary width) Type-MA (Vertical Combination Mull); DP +65/-65 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=A3	960mm trib width	2504mm span	ESP009335P-1205 Rev. 3	3/14/2016	8/3/2026
413-H-1222.17	Ultra Outswing Entrance Door onelite, w/raised panels, opaque, EE, HP (R&D 11160)	101/I.S.2/A440-11	Class LC-PG65; Size Tested 968mm x 2504mm Type-FD; DP +65/-65 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=A3	968mm	2504mm	ESP009335P-1205 Rev. 3	3/14/2016	8/3/2026
413-H-1222.18	Ultra Outswing Entrance Door onelite, w/raised panels, opaque, EE, HP (R&D 11160)	101/I.S.2/A440-11	Class LC-PG65; Size Tested 1902mm x 2504mm Type-SHD; DP +65/-65 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=A3	1902mm	2504mm	ESP009335P-1205 Rev. 3	3/14/2016	8/3/2026

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  John McFee, VP of Certification Programs, WDMA Hallmark

By:  Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com