NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015625.02

DATE: <u>08/22/2022</u>

CERTIFICATION PROGRAM: <u>Structural</u>

COMPANY: Croft

CODE: <u>1887-1</u>

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Croft, LLC	Series "4400/4440"
1800 North Clark Avenue	Aluminum Single Hung Window
Magnolia, MS 39652	
	Configuration: O/X Glazing: Insulating Glass (Annealed)
	Frame: W-899mm(35.38") H-1816mm(71.5")
	Sash: W-838mm(33") H-908mm(35.75")
	DLO: W-784mm(30.88") H-826mm(32.5")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG50 899 x 1816* (36 x 72*)-H Design Pressure: ±2400 Pa (50 psf)
	Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Architectural Testing, Inc.

Report No: F3541.01-801-47/B7505.01-801-47

Expiration Date: August 31, 2026

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124 nami@namiinc.com