NOTICE OF PRODUCT CERTIFICATION



CENTIFIC	LATION NO:
	DATE
CERTIFICATION	PROGRAM
	COMPANY
	CODE

CEDTIFIC ATION N

NI015625.03
08/22/2022
Structural
Croft
1887-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS		PRODUCT DES	CRIPTION
Croft, LLC	Series "4400/4440"		
1800 North Clark Avenue	Twir	n Aluminum Singl	e Hung Window
Magnolia, MS 39652	(w/Continuous Head & Sill)		
		Configuration: Glazing: Insulating Gl	
	Frame:	W-1797mm(70.75")	H-1816mm(71.5")
	Sash:	W-838mm(33")	H-908mm(35.75")
	DLO:	W-784mm(30.88")	H-826mm(32.5")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class R-PG50 1797 x 1816* (71 x 72*)-H
AAMA/WDMA/CSA 101/I.S.2/A440-08	Design Pressure: ±2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Report No: Expiration Date: Architectural Testing, Inc. F3542.01-801-47/B7505.01-801-47 August 31, 2026

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124 nami@namiinc.com