

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011401-R7  
DATE: 01/14/2013  
CERTIFICATION PROGRAM: Structural  
COMPANY: JELD-WEN  
CODE: 1822-1  
REVISION DATE: 06/20/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b> <b>3737 Lakeport Boulevard</b> <b>Klamath Falls, OR 97601</b>	<b>“Contours” Premium Steel Door w/Steel</b> <b>Edge Opaque In-Swing Door</b> <b>w/Dunbarton Redi-Flex 90. Min Steel</b> <b>Frame &amp; Standard AFCO Threshold</b>  Configuration: X  Frame: W-990mm(38.94") H-2201mm(86.63") Panel: W-909mm(35.75") H-2005mm(83.25")

SPECIFICATION	PRODUCT RATING
<b>TAS 201/202/203-94</b>	<b>Design Pressure: 3161 Pa (66 psf)</b> <b>Negative Design Pressure: 3161 Pa (66 psf)</b> Water Penetration Resistance Test Pressure: 0 Pa (0 psf) <b>Large Missile Impact Rated</b> Qualifies Configurations: X

Product Tested By: National Certified Testing Laboratories/Certified Testing Laboratories, Inc.  
Report No: NCTL-210-3844-1/NCTL-210-3844-1A/CTLA1167W-1/CTLA-1167W-2A/W-1546/W-1788/W-1819/W-1897/W-1905  
Expiration Date: October 31, 2026

Administrator's Signature:  \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023