

NOTICE OF PRODUCT CERTIFICATION



Company: ProVia LLC
2150 State Route 39
Sugarcreek, OH 44681

Certification No.: NI010709.04-R4
Certification Date: 07/14/2011
Expiration Date: 12/31/2026
Revision Date: 11/17/2022

Product: Fiberglass Glazed Inswing or Outswing Door w/ and w/o Non-Impact Rated Sidelites
(w/Wood Frame unless noted)

Specification: TAS 202-94/ASTM E330

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Design Pressure Pos/Neg	Water Test Pressure	Missile Impact Rated	Test Report Number Drawing Number & Comments
X Single	I/S	Glazed	3'0" x 8'0"	+40/-45	2.86 psf	No	NCTL-210-3107-1/CTLA-805W/W-1978 Maximum Panel Size: 3'0" x 8'0"
X Single	O/S	Glazed	3'0" x 8'0"	+40/-47	6.00 psf	No	NCTL-210-3107-1/CTLA-805W/W-1978 Maximum Panel Size: 3'0" x 8'0"
XX Double	I/S	Glazed	6'0" x 8'0"	+40/-45	2.86 psf	No	NCTL-210-3107-1/CTLA-805W/W-1978 Maximum Panel Size: 3'0" x 8'0"
XX Double	O/S	Glazed	6'0" x 8'0"	+40/-47	6.00 psf	No	NCTL-210-3107-1/CTLA-805W/W-1978 Maximum Panel Size: 3'0" x 8'0"
XO/OX Single w/Sidelites	I/S	Glazed Door Glazed Sidelites	6'0" x 8'0"	+40/-45	2.86 psf	Door-No Sidelites-No	NCTL-210-3107-1/CTLA-805W/W-1978 Maximum Panel Size: 3'0" x 8'0"
XO/OX Single w/Sidelites	O/S	Glazed Door Glazed Sidelites	6'0" x 8'0"	+40/-47	6.00 psf	Door-No Sidelites-No	NCTL-210-3107-1/CTLA-805W/W-1978 Maximum Panel Size: 3'0" x 8'0"
OXO Single w/Sidelites	I/S	Glazed Door Glazed Sidelites	9'0" x 8'0"	+40/-45	2.86 psf	Door-No Sidelites-No	NCTL-210-3107-1/CTLA-805W/W-1978 Maximum Panel Size: 3'0" x 8'0"
OXO Single w/Sidelites	O/S	Glazed Door Glazed Sidelites	9'0" x 8'0"	+40/-47	6.00 psf	Door-No Sidelites-No	NCTL-210-3107-1/CTLA-805W/W-1978 Maximum Panel Size: 3'0" x 8'0"
OXXO Double w/Sidelites	I/S	Glazed Door Glazed Sidelites	12'6" x 8'0"	+40/-45	2.86 psf	Door-No Sidelites-No	NCTL-210-3107-1/CTLA-805W/W-1978 Maximum Panel Size: 3'0" x 8'0"
OXXO Double w/Sidelites	O/S	Glazed Door Glazed Sidelites	12'6" x 8'0"	+40/-47	6.00 psf	Door-No Sidelites-No	NCTL-210-3107-1/CTLA-805W/W-1978 Maximum Panel Size: 3'0" x 8'0"

National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072

Tel: (804) 684-5124/Email: nami@namiinc.com

NAMI AUTHORIZED SIGNATURE: _____