

NOTICE OF PRODUCT CERTIFICATION



Company: ProVia LLC
 2150 State Route 39
 Sugarcreek, OH 44681

Certification No.: NI010709.16-R3
Certification Date: 07/14/2011
Expiration Date: 12/31/2026
Revision Date: 11/17/2022

Product: Fiberglass Opaque Inswing or Outswing Door w/ and w/o Sidelites
 (w/Wood Frame unless noted)(Schlage/Emtek)

Specification: ASTM E330

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Design Pressure Pos/Neg	Water Test Pressure	Missile Impact Rated	Test Report Number Drawing Number & Comments
X Single	I/S	Opaque	3'0" x 6'8"	+64.2/-64.2	2.86 psf	No	NCTL-210-3358-1/W-1489 Maximum Panel Size: 3'0" x 6'8"
X Single	O/S	Opaque	3'0" x 6'8"	+64.2/-64.2	10.5 psf	No	NCTL-210-3358-1/CTLA-772W/W-1489 Maximum Panel Size: 3'0" x 6'8"
XX Double	I/S	Opaque	6'0" x 6'8"	+50.5/-50.5	2.86 psf	No	NCTL-210-3105-1/210-3314-1A/CTLA-772W-2/W-1489 Maximum Panel Size: 3'0" x 6'8"/Sidelite: 3'0" x 6'8"
XX Double	O/S	Opaque	6'0" x 6'8"	+55/-50.5	6.00 psf 8.25 psf*	No	NCTL-210-3105-1/210-3314-1A/CTLA-772W-2/W-1489 Maximum Panel Size: 3'0" x 6'8"/Sidelite: 3'0" x 6'8"
XO/OX Single w/Sidelites	I/S	Opaque Door Glazed Sidelites	6'0" x 6'8"	+50.5/-50.5	2.86 psf	Door-No Sidelites-No	NCTL-210-3105-1/210-3314-1A/CTLA-772W-2/W-1489 Maximum Panel Size: 3'0" x 6'8"/Sidelite: 3'0" x 6'8"
XO/OX Single w/Sidelites	O/S	Opaque Door Glazed Sidelites	6'0" x 6'8"	+55/-50.5	6.00 psf 8.25 psf*	Door-No Sidelites-No	NCTL-210-3105-1/210-3314-1A/CTLA-772W-2/W-1489 Maximum Panel Size: 3'0" x 6'8"/Sidelite: 3'0" x 6'8"
OXO Single w/Sidelites	I/S	Opaque Door Glazed Sidelites	9'0" x 6'8"	+50.5/-50.5	2.86 psf	Door-No Sidelites-No	NCTL-210-3105-1/210-3314-1A/CTLA-772W-2/W-1489 Maximum Panel Size: 3'0" x 6'8"/Sidelite: 3'0" x 6'8"
OXO Single w/Sidelites	O/S	Opaque Door Glazed Sidelites	9'0" x 6'8"	+55/-50.5	6.00 psf 8.25 psf*	Door-No Sidelites-No	NCTL-210-3105-1/210-3314-1A/CTLA-772W-2/W-1489 Maximum Panel Size: 3'0" x 6'8"/Sidelite: 3'0" x 6'8"
OXXO Double w/Sidelites	I/S	Opaque Door Glazed Sidelites	12'4" x 6'8"	+50.5/-50.5	2.86 psf	Door-No Sidelites-No	NCTL-210-3105-1/210-3314-1A/CTLA-772W-2/W-1489 Maximum Panel Size: 3'0" x 6'8"/Sidelite: 3'0" x 6'8"
OXXO Double w/Sidelites	O/S	Opaque Door Glazed Sidelites	12'4" x 6'8"	+55/-50.5	6.00 psf 8.25 psf*	Door-No Sidelites-No	NCTL-210-3105-1/210-3314-1A/CTLA-772W-2/W-1489 Maximum Panel Size: 3'0" x 6'8"/Sidelite: 3'0" x 6'8"

*Denotes High Dam Threshold Design

National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072

Tel: (804) 684-5124/Email: nami@namiinc.com

A handwritten signature in black ink, appearing to be 'S.M.D.' or similar, written in a cursive style.

NAMI AUTHORIZED SIGNATURE: _____