


# NOTICE OF PRODUCT CERTIFICATION



**Company:** ProVia LLC  
 2150 State Route 39  
 Sugarcreek, OH 44681

**Certification No.:** NI010709.19-R3  
**Certification Date:** 07/14/2011  
**Expiration Date:** 12/31/2026  
**Revision Date:** 11/17/2022

**Product:** Fiberglass Opaque Inswing or Outswing Door w/ and w/o Sidelites  
 (w/Wood Frame unless noted)(Schlage/Emtek)

**Specification:** ASTM E330

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Design Pressure Pos/Neg	Water Test Pressure	Missile Impact Rated	Test Report Number Drawing Number & Comments
X Single	I/S	Opaque	3'0" x 8'0"	+51/-51	2.86 psf	No	NCTL-210-3102-1/CTLA-772W/1051W/W-1489 Maximum Panel Size: 3'0" x 8'0"
X Single	O/S	Opaque	3'0" x 8'0"	+51/-51	10.5 psf	No	NCTL-210-3102-1/CTLA-772W/1051W/W-1489 Maximum Panel Size: 3'0" x 8'0"
XX Double	I/S	Opaque	6'0" x 8'0"	+50.5/-50.5	2.86 psf	No	NCTL-210-3105-1/210-3314-1A/CTLA-772W-2/W-1489 Maximum Panel Size: 3'0" x 8'0"/Sidelite: 3'0" x 8'0"
XX Double	O/S	Opaque	6'0" x 8'0"	+55/-50.5	6.00 psf 8.25 psf*	No	NCTL-210-3105-1/210-3314-1A/CTLA-772W-2/W-1489 Maximum Panel Size: 3'0" x 8'0"/Sidelite: 3'0" x 8'0"
XO/OX Single w/Sidelites	I/S	Opaque Door Glazed Sidelites	6'0" x 8'0"	+50.5/-50.5	2.86 psf	Door-No Sidelites-No	NCTL-210-3105-1/210-3314-1A/CTLA-772W-2/W-1489 Maximum Panel Size: 3'0" x 8'0"/Sidelite: 3'0" x 8'0"
XO/OX Single w/Sidelites	O/S	Opaque Door Glazed Sidelites	6'0" x 8'0"	+55/-50.5	6.00 psf 8.25 psf*	Door-No Sidelites-No	NCTL-210-3105-1/210-3314-1A/CTLA-772W-2/W-1489 Maximum Panel Size: 3'0" x 8'0"/Sidelite: 3'0" x 8'0"
OXO Single w/Sidelites	I/S	Opaque Door Glazed Sidelites	9'0" x 8'0"	+50.5/-50.5	2.86 psf	Door-No Sidelites-No	NCTL-210-3105-1/210-3314-1A/CTLA-772W-2/W-1489 Maximum Panel Size: 3'0" x 8'0"/Sidelite: 3'0" x 8'0"
OXO Single w/Sidelites	O/S	Opaque Door Glazed Sidelites	9'0" x 8'0"	+55/-50.5	6.00 psf 8.25 psf*	Door-No Sidelites-No	NCTL-210-3105-1/210-3314-1A/CTLA-772W-2/W-1489 Maximum Panel Size: 3'0" x 8'0"/Sidelite: 3'0" x 8'0"
OXXO Double w/Sidelites	I/S	Opaque Door Glazed Sidelites	12'4" x 8'0"	+50.5/-50.5	2.86 psf	Door-No Sidelites-No	NCTL-210-3105-1/210-3314-1A/CTLA-772W-2/W-1489 Maximum Panel Size: 3'0" x 8'0"/Sidelite: 3'0" x 8'0"
OXXO Double w/Sidelites	O/S	Opaque Door Glazed Sidelites	12'4" x 8'0"	+55/-50.5	6.00 psf 8.25 psf*	Door-No Sidelites-No	NCTL-210-3105-1/210-3314-1A/CTLA-772W-2/W-1489 Maximum Panel Size: 3'0" x 8'0"/Sidelite: 3'0" x 8'0"

\*Denotes High Dam Threshold Design

National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072

Tel: (804) 684-5124/Email: [nami@namiinc.com](mailto:nami@namiinc.com)

A handwritten signature in black ink, appearing to be 'Shelby' or similar, written over a horizontal line.

NAMI AUTHORIZED SIGNATURE: \_\_\_\_\_