


NOTICE OF PRODUCT CERTIFICATION



Company: ProVia LLC
 2150 State Route 39
 Sugarcreek, OH 44681

Certification No.: NI010709.22-R1
Certification Date: 05/09/2019
Expiration Date: 12/31/2026
Revision Date: 11/17/2022

Product: Fiberglass Opaque Inswing or Outswing Door w/ and w/o Non-Impact Rated Sidelites
 (w/Fusion Frame)(Trilennium)

Specification: ASTM E330/ASTM E1886/E1996

Impact Rating: Wind Zone 4-Missile Level D

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Design** Pressure Pos/Neg (w/o Water)	Water Test Pressure	Missile Impact Rated	Test Report Number Drawing Number & Comments
X Single	I/S	Opaque	3'0" x 8'0"	+50/-50	2.86 psf	Yes	NCTL-210-3102-1/CTLA-772W/1051W/W-1489/W-1902 Maximum Panel Size: 3'0" x 8'0"
X Single	O/S	Opaque	3'0" x 8'0"	+50/-50	10.5 psf	Yes	NCTL-210-3102-1/CTLA-772W/1051W/W-1489/W-1902 Maximum Panel Size: 3'0" x 8'0"
XX Double	I/S	Opaque	6'0" x 8'0"	+50/-50	2.86 psf	Yes	NCTL-210-3105-1/210-3314-1A/CTLA-772W-2/W-1489/W-1902 Maximum Panel Size: 3'0" x 8'0"/Sidelite: 3'0" x 8'0"
XX Double	O/S	Opaque	6'0" x 8'0"	+50/-50	6.00 psf 8.25 psf*	Yes	NCTL-210-3105-1/210-3314-1A/CTLA-772W-2/W-1489/W-1902 Maximum Panel Size: 3'0" x 8'0"/Sidelite: 3'0" x 8'0"
XO/OX Single w/Sidelites	I/S	Opaque Door Glazed Sidelites	6'0" x 8'0"	+50/-50	2.86 psf	Door-Yes Sidelites-No	NCTL-210-3105-1/210-3314-1A/CTLA-772W-2/W-1489/W-1902 Maximum Panel Size: 3'0" x 8'0"/Sidelite: 3'0" x 8'0"
XO/OX Single w/Sidelites	O/S	Opaque Door Glazed Sidelites	6'0" x 8'0"	+50/-50	6.00 psf 8.25 psf*	Door-Yes Sidelites-No	NCTL-210-3105-1/210-3314-1A/CTLA-772W-2/W-1489/W-1902 Maximum Panel Size: 3'0" x 8'0"/Sidelite: 3'0" x 8'0"
OXO Single w/Sidelites	I/S	Opaque Door Glazed Sidelites	9'0" x 8'0"	+50/-50	2.86 psf	Door-Yes Sidelites-No	NCTL-210-3105-1/210-3314-1A/CTLA-772W-2/W-1489/W-1902 Maximum Panel Size: 3'0" x 8'0"/Sidelite: 3'0" x 8'0"
OXO Single w/Sidelites	O/S	Opaque Door Glazed Sidelites	9'0" x 8'0"	+50/-50	6.00 psf 8.25 psf*	Door-Yes Sidelites-No	NCTL-210-3105-1/210-3314-1A/CTLA-772W-2/W-1489/W-1902 Maximum Panel Size: 3'0" x 8'0"/Sidelite: 3'0" x 8'0"
OXXO Double w/Sidelites	I/S	Opaque Door Glazed Sidelites	12'4" x 8'0"	+50/-50	2.86 psf	Door-Yes Sidelites-No	NCTL-210-3105-1/210-3314-1A/CTLA-772W-2/W-1489/W-1902 Maximum Panel Size: 3'0" x 8'0"/Sidelite: 3'0" x 8'0"
OXXO Double w/Sidelites	O/S	Opaque Door Glazed Sidelites	12'4" x 8'0"	+50/-50	6.00 psf 8.25 psf*	Door-Yes Sidelites-No	NCTL-210-3105-1/210-3314-1A/CTLA-772W-2/W-1489/W-1902 Maximum Panel Size: 3'0" x 8'0"/Sidelite: 3'0" x 8'0"

*Denotes High Dam Threshold Design **All Design Pressure without water test

National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072
Tel: (804) 684-5124/Email: nami@namiinc.com

A handwritten signature in black ink, appearing to be 'Shelby' or similar, written over a horizontal line.

NAMI AUTHORIZED SIGNATURE: _____