

# Hallmark® Certificate of Conformance and License (CCL)




Kolbe & Kolbe Millwork Co.  
1323 South 11th Avenue  
Wausau, WI 54401

Mfr ID: 413  
For more Information visit [www.amscert.com](http://www.amscert.com)  
Website: [www.kolbewindows.com](http://www.kolbewindows.com)  
TEL:

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
413-H-1204.26	Ultra Beveled Direct Set non reinforced combination mull (R&D 22038)	101/I.S.2/A440-17	Class LC-PG65; Size Tested 2134mm span/914mm trib width (~84/36) Type-MA; (Vertical Non-reinforced Combination Mullion); DP +65/-65 psf; Water Test Press 510Pa (10.65psf); Can. Air Infil/Exfil. Level=Fixed	914mm	2134mm	QCT22-6595.21	2/24/2023	11/28/2032
413-H-1204.27	Ultra Beveled Direct Set non reinforced combination mull (R&D 22038)	AAMA 450-10	Class LC-PG65; Size Tested 2134mm span/914mm trib width (~84/36) Type-MA; (Vertical Non-reinforced Combination Mullion); DP +65/-65 psf; Water Test Press 510Pa (10.65psf); Can. Air Infil/Exfil. Level=Fixed	914mm	2134mm	QCT22-6595.21	2/24/2023	11/28/2032
413-H-1204.28	Ultra Beveled Direct Set non reinforced combination mull (R&D 22038)	CSA A440 S1-19	Class LC-PG65; Size Tested 2134mm span/914mm trib width (~84/36) Type-MA; (Vertical Non-reinforced Combination Mullion); DP +3120/-3120 Pa; Water Test Press 510Pa; Can. Air Infil/Exfil. Level=Fixed	914mm	2134mm	QCT22-6595.21	2/24/2023	11/28/2032

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  John McFee, VP of Certification Programs, WDMA Hallmark

By:  Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor:  
Window and Door Manufacturers Assoc  
330 N. Wabash Avenue, Suite 2000  
Chicago, IL 60611  
TEL (312)673-4828 [www.wdma.com](http://www.wdma.com)

Program Administrator:  
Administrative Management Systems, Inc.  
PO Box 730, 205 West Main  
Sackets Harbor, NY 13685  
TEL (315)646-2234 [staff@amscert.com](mailto:staff@amscert.com)