

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI006317.01-R2  
**DATE:** 11/29/2005  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Regency  
**CODE:** 750-1  
**REVISION DATE:** 10/11/2021

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Regency Plus, Inc.</b> <b>2000 Locust Gap Highway</b> <b>Mount Carmel, PA 17851</b>	<b>Series "5105"</b> <b>Vinyl Fixed Window</b>  Configuration: O Glazing: IG-3/16" Tempered Glass/Laminate- 3/16" Annealed Glass/0.100" PVB Solutia Interlayer/ 3/16" Annealed Glass  Frame: W-1829mm(72") H-1829mm(72") DLO: W-1676mm(66") H-1676mm(66")

SPECIFICATION	PRODUCT RATING
<b>TAS 201/202/203-94</b> <b>ASTM F588-02</b>	<b>Design Pressure: ±2633 Pa (55 psf)</b> <b>Large Missile Impact Rated</b> <b>FER-Passed Level 10</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-9699-1/W-1901/W-1979  
Expiration Date: September 30, 2027

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122