

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI009490-R5
DATE: 05/30/2008
CERTIFICATION PROGRAM: Structural
COMPANY: Regency
CODE: 750-1
REVISION DATE: 05/08/2019

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Regency Plus, Inc. 2000 Locust Gap Highway Mount Carmel, PA 17851	Series "5108" Impact Rated Vinyl Fixed Window Configuration: O Glazing: IG-1/8" Tempered Glass/Laminate- 1/8" Annealed Glass/0.090" DuPont Interlayer/ 1/8" Annealed Glass Frame: W-1524mm(60") H-1524mm(60") DLO: W-1384mm(54.5") H-1384mm(54.5")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94 ASTM F588-02	Design Pressure: ±2633 Pa (55 psf) Large Missile Impact Rated FER-Passed

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-11363-1/W-1901
Expiration Date: May 31, 2027

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122